

MEMORANDUM

Date: 06/22/2023
To: Michael Elabarger
From: Jacqueline Thompson, PE
Subject: Wallbrook Lot 11 – 7-Eleven
SPD-23-04, 2nd Submittal
Town of Rolesville, NC

This memo summarizes the review of construction infrastructure drawings submitted by ARK Consulting Group, PLLC, dated 05/01/23 (received 06/01/23).

Sheet C1.0:

1. Bring text to front for legibility.
 - a. This comment applies to all sheets.
2. Adjust grading limits or LOD and silt fence to encompass all grading limits.
 - a. Adjust total LOD if anything changes due to comment 2.

Sheet C2.0:

3. The south most “parking space” on the west side of the building does not appear to be wide enough for an actual parking space. This area should be hatched/striped if not. If part of a handicap space, it should be marked or signed accordingly. Please adjust accordingly to clarify intent for this space.

