

# ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH CURRENT TOWN OF ROLESVILLE STANDARDS AND SPECIFICATIONS

## SYMBOLS AND ABBREVIATIONS

ABC	AGGREGATE BASE COURSE	—	EXISTING CURB INLET
ALUM	ALUMINUM	□	EXISTING GRATE INLET/YARD INLET
AST2	ALUMINIZED STEEL - TYPE 2	—	EXISTING FLARED END SECTION
B-B	BACK TO BACK	⊕	EXISTING FIRE HYDRANT
BOA	BLOW-OFF ASSEMBLY	—	EXISTING BLOW-OFF ASSEMBLY
C&G	CURB AND GUTTER	—	EXISTING GATE VALVE
CF	CUBIC FEET PER SECOND	—	EXISTING REDUCER
CI	CURB INLET	—	EXISTING WATER METER
CL	CENTER LINE	—	EXISTING SAN SEWER MANHOLE
CMP	CORRUGATED METAL PIPE	—	EXISTING CLEAN OUT
CO	CLEAN OUT	—	EXISTING POWER POLE
COM	COMMUNICATION	—	EXISTING TELEPHONE PEDESTAL
CONC	CONCRETE	—	EXISTING AREA LIGHT
DCV	DOUBLE CHECK VALVE	—	EXISTING SIGN
DDCV	DOUBLE DETECTOR CHECK VALVE	—	NEW CURB INLET
DI	DROP INLET	—	NEW GRATE INLET/YARD INLET
DIP	DUCTILE IRON PIPE	—	NEW FLARED END SECTION
EASE	EASEMENT	—	NEW FIRE HYDRANT
ELEC	ELECTRIC	—	NEW BLOW-OFF ASSEMBLY
EX	EXISTING	—	NEW GATE VALVE
FES	FLARED END SECTION	—	NEW REDUCER
FH	FIRE HYDRANT	—	NEW WATER METER
FM	FORCE MAIN	—	NEW TEE
FT	FEET	—	NEW PLUG
FT/SEC	FEET PER SEC	—	NEW MANHOLE
GALV	GALVANIZED	—	NEW CLEAN OUT
GV	GATE VALVE	—	NEW SIGN
HDPE	HIGH DENSITY POLYETHYLENE	—	IRON PIPE
L	LENGTH	—	BENCHMARK
LF	LINEAR FEET	—	—
MH	MANHOLE	—	—
PAVE	PAVEMENT	—	—
PE	FINISHED PAD ELEVATION	—	—
PP	POWER POLE	—	—
PVC	POLYVINYL CHLORIDE	—	—
R	RADIUS	—	—
R/W	RIGHT-OF-WAY	—	—
RED	REDUCER	—	—
RCP	REINFORCED CONCRETE PIPE	—	—
RPZ	REDUCED PRESSURE ZONE	—	—
SS	SANITARY SEWER	—	—
STA	STATION	—	—
TDD	TEMPORARY DIVERSION DITCH	—	—
TELE	TELEPHONE	—	—
TSB	TEMPORARY SEDIMENT BASIN	—	—
UG	UNDERGROUND	—	—
WCR	WHEELCHAIR RAMP	—	—
W/L	WATER LINE	—	—
WM	WATER METER	—	—
YI	YARD INLET	—	—

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT


# COBBLESTONE VILLAGE MIXED USE DEVELOPMENT

## TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

# CONSTRUCTION DRAWINGS

## TOWN OF ROLESVILLE PROJECT NO. SITE PLAN APPLICATION NO. CUP-SB-21-01

### CASE NO. SP21-01



**Public**  
**Water Distribution / Extension System**  
The City of Raleigh consents to the connection and extension of the City's public water system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
City of Raleigh  
Public Utilities Department Permit # W-3879  
Authorization to Construct See digital signature

**Private**  
**Sewer Collection / Extension System**  
The City of Raleigh consents to the connection to its public sewer system and extension of the private sewer collection system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
City of Raleigh  
Public Utilities Department Permit # S-4962 (P)  
Authorization to Construct See digital signature

### SITE PERMITTING APPROVAL

#### Water and Sewer Permits (if applicable)

The City of Raleigh consents to the connection and extension of the City's Public Sewer System as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Raleigh Public Utilities Department Permit # W-3879

The City of Raleigh consents to the connection and extension of the City's Public Water System as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Raleigh Public Utilities Department Permit # S-2892 (P)

The City of Raleigh consents to the connection to its public sewer system and extension of the private sewer collection system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.

City of Raleigh Public Utilities Department Permit #

#### CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. The approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval  
Raleigh Water Review Officer

#### OWNER:

**COBBLESTONE CROSSING SPE, LLC**  
8480 HONEYCUTT ROAD, STE 200  
RALEIGH, NC 27615

#### DEVELOPER:

**KDM DEVELOPMENT CORPORATION**  
1080 PITTSFORD VICTOR RD, STE 202  
PITTSFORD NY 14534-3805

**CONTACT: KENYON BURHNAM**  
**PHONE: 585-465-0099**  
**EMAIL: KENYON@KDMDEVELOPMENT.COM**

## SHEET INDEX

COVER	
C0.1	EXISTING CONDITIONS & DEMOLITION PLAN
C1.1	SITE PLAN
C1.2	OPEN SPACE PLAN
C2.1	UTILITY PLAN
C3.1	GRADING AND DRAINAGE PLAN
C3.2	BMP DETAILS
C3.3	EROSION CONTROL PLAN - STAGE 1
C3.4	EROSION CONTROL PLAN - STAGE 2
C3.5	EROSION CONTROL DETAILS
C3.6	EROSION CONTROL DETAILS
C3.7	NGC01 PLAN
C3.8	STORM DRAINAGE PIPE & STRUCTURE TABLE
C4.1	PUBLIC WATERLINE PROFILE
C4.2	SANITARY SEWER PROFILE
C4.3	S. MAIN ST. - U.S. 401 WIDENING CROSS SECTIONS
L1.1	LANDSCAPE PLAN
L1.2	LANDSCAPE DETAILS
SL-101	LIGHTING PLAN
C5.1	DETAILS
C5.2	DETAILS
C5.3	DETAILS
C5.4	DETAILS
C5.5	DETAILS
C5.6	DETAILS
A04	EXTERIOR ELEVATIONS - BUILDING 4
A05	EXTERIOR ELEVATIONS - BUILDING 5
A08	EXTERIOR ELEVATIONS - BUILDING 8
A09	EXTERIOR ELEVATIONS - MAIL KIOSK



SP 21-01 REVISION / Site/Construction Plan  
Cobblestone Village  
**APPROVED**  
Date: April 23, 2024

*Marty D. Bizzell*  
Town of Rolesville Planning Department

#### ENGINEER:



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
6310 CHAPEL HILL ROAD, SUITE 250  
RALEIGH, NORTH CAROLINA 27607  
**TELEPHONE: (919) 851-4422**  
**FAX: (919) 851-8968**

**CERTIFICATION NUMBERS: NCBELS (C-0110)**  
**NCBOLA (C-0267)**

**CONTACT: MARTY D. BIZZELL, PE, CPESC**  
**EMAIL: Marty.Bizzell@BNKinc.com**



04/19/24

### EROSION CONTROL, STORMWATER AND FLOODPLAIN MANAGEMENT

**APPROVED**  
EROSION CONTROL  S-  
STORMWATER MGMT.  S-  
FLOOD STUDY  S-  
DATE \_\_\_\_\_




## CONSTRUCTION NOTES

- ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH APPLICABLE MUNICIPALITY STANDARDS, SPECIFICATIONS, AND DETAILS. WORK IN THIS PROJECT SHALL ALSO CONFORM TO THESE PLANS, THE LATEST EDITIONS OF THE NORTH CAROLINA DEPARTMENT OF TRANSPORTATION (NCDOT) ROAD AND BRIDGE SPECIFICATIONS, THE ROAD AND BRIDGE STANDARDS, THE NORTH CAROLINA EROSION AND SEDIMENT CONTROL HANDBOOK, THE NORTH CAROLINA EROSION AND SEDIMENT CONTROL REGULATIONS, THE FINAL GEOTECHNICAL REPORT, AND GENERAL DESIGN STANDARDS. IN THE EVENT OF CONFLICT BETWEEN ANY OF THESE STANDARDS, SPECIFICATIONS, OR PLANS, THE MOST STRINGENT SHALL GOVERN.
- THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR TRENCH SAFETY DURING ALL PHASES OF CONSTRUCTION.
- THE LOCATION AND SIZE OF EXISTING UTILITIES AS SHOWN IS APPROXIMATE ONLY. THE CONTRACTOR IS RESPONSIBLE FOR HORIZONTALLY AND VERTICALLY LOCATING AND PROTECTING ALL PUBLIC OR PRIVATE UTILITIES WHICH LIE IN OR ADJACENT TO THE CONSTRUCTION SITE. AT LEAST 48 HOURS PRIOR TO ANY DEMOLITION, GRADING, OR CONSTRUCTION ACTIVITY, THE CONTRACTOR SHALL NOTIFY THE NORTH CAROLINA ONE-CALL UTILITIES LOCATION SERVICE (ULOC) AT 1-800-632-4949 FOR PROPER IDENTIFICATION OF EXISTING UTILITIES WITHIN THE SITE.
- THE CONTRACTOR SHALL SALVAGE AND PROTECT ALL EXISTING POWER POLES, SIGNS, MANHOLES, TELEPHONE RISERS, WATER VALVES, ETC. DURING ALL CONSTRUCTION PHASES. THE CONTRACTOR SHALL REPAIR, AT HIS OWN EXPENSE, ANY EXISTING UTILITIES DAMAGED DURING CONSTRUCTION.
- TRAFFIC CONTROL ON PUBLIC STREETS SHALL BE IN CONFORMANCE WITH THE TRAFFIC CONTROL PLAN, THE MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES, AND AS FURTHER DIRECTED BY CITY AND STATE INSPECTORS.
- ANY DISCREPANCIES FOUND BETWEEN THE DRAWINGS AND SPECIFICATIONS AND SITE CONDITIONS OR ANY INCONSISTENCIES OR AMBIGUITIES IN DRAWINGS OR SPECIFICATIONS SHALL BE IMMEDIATELY REPORTED TO THE ENGINEER, IN WRITING, WHO SHALL PROMPTLY ADDRESS SUCH INCONSISTENCIES OR AMBIGUITIES. WORK DONE BY THE CONTRACTOR AFTER HIS DISCOVERY OF SUCH DISCREPANCIES, INCONSISTENCIES, OR AMBIGUITIES SHALL BE DONE AT THE CONTRACTOR'S RISK.
- A PRE-CONSTRUCTION CONFERENCE SHALL BE HELD PRIOR TO THE START OF CONSTRUCTION. THE CONTRACTOR SHALL ARRANGE THE MEETING WITH THE CITY ENGINEERING DIVISION.
- CONTRACTOR IS RESPONSIBLE FOR VERIFYING ALL REQUIRED PERMITS AND APPROVALS PRIOR TO COMMENCING CONSTRUCTION.
- ALL AREAS SHALL BE GRADED FOR POSITIVE DRAINAGE, AND AS SHOWN ON THESE PLANS, THE CONTRACTOR SHALL MAINTAIN ADEQUATE SITE DRAINAGE DURING ALL PHASES OF CONSTRUCTION. THE CONTRACTOR SHALL USE SILT FENCES (OR OTHER METHODS APPROVED BY THE ENGINEER AND APPLICABLE MUNICIPALITY) AS REQUIRED TO PREVENT SILT AND CONSTRUCTION DEBRIS FROM FLOWING ONTO ADJACENT PROPERTIES. CONTRACTOR SHALL COMPLY WITH ALL APPLICABLE FEDERAL, STATE, OR LOCAL EROSION, CONSERVATION, AND SILTATION ORDINANCES. CONTRACTOR SHALL REMOVE ALL TEMPORARY EROSION CONTROL DEVICES UPON COMPLETION OF PERMANENT DRAINAGE FACILITIES AND THE ESTABLISHMENT OF A STAND OF GRASS OR OTHER GROWTH TO PREVENT EROSION.
- THE CONTRACTOR SHALL CLEAR AND GRUB THE SITE AND PLACE, COMPACT, AND MOISTURE CONDITION ALL FILL PER THE PROJECT GEOTECHNICAL ENGINEER'S SPECIFICATIONS. THE FILL MATERIAL TO BE USED SHALL BE APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACEMENT.
- MATERIALS USED TO CONSTRUCT EMBANKMENTS FOR ANY PURPOSE, BACKFILL AROUND DRAINAGE STRUCTURES, OR IN UTILITY TRENCHES FOR ANY OTHER DEPRESSION REQUIRING FILL OR BACKFILL SHALL BE COMPACTED TO 95% OF MAXIMUM DENSITY AS DETERMINED BY THE STANDARD PROCTOR TEST AS SET OUT IN ASTM STANDARD D998. STONE BACKFILL SHALL BE COMPACTED TO 95% MAXIMUM DENSITY AS DETERMINED BY THE MODIFIED PROCTOR TEST AS SET OUT IN ASTM STANDARD D1557. THE CONTRACTOR SHALL, PRIOR TO ANY OPERATIONS INVOLVING FILLING OR BACKFILLING, SUBMIT THE RESULTS OF THE PROCTOR TEST TOGETHER WITH A CERTIFICATION THAT THE SOIL TESTED IS REPRESENTATIVE OF THE MATERIALS TO BE USED ON THE PROJECT. TESTS SHALL BE CONDUCTED BY A CERTIFIED MATERIALS TESTING LABORATORY AND THE CERTIFICATIONS MADE BY A LICENSED PROFESSIONAL ENGINEER REPRESENTING THE LABORATORY.
- PROPOSED CONTOURS AND GUTTER GRADIENTS ARE APPROXIMATE. PROPOSED SPOT ELEVATIONS AND ROADWAY PROFILES/SUPERELEVATIONS ARE TO BE USED IN CASE OF DISCREPANCY.
- THE CONTRACTOR SHALL REVIEW, VERIFY AND COORDINATE ALL DIMENSIONS SHOWN ON PLANS, INCLUDING THE HORIZONTAL AND VERTICAL LOCATION OF CURB INLETS AND GRATE INLETS AND ALL UTILITIES CROSSING THE STORM SEWER PRIOR TO STARTING PROJECT.
- ALL CURB JOINTS SHALL EXTEND THROUGH THE CURB. MINIMUM LENGTH OF OFFSET JOINTS AT RADIUS POINTS IS 1.5 FEET. ALL JOINTS SHALL BE SEALED WITH JOINT SEALANT.
- ALL HANDICAP RAMPING, STRIPING, AND PAVEMENT MARKINGS SHALL CONFORM TO ADA REQUIREMENTS AND THE NORTH CAROLINA STATE BUILDING CODE, VOL. 1-C ACCESSIBILITY CODE.
- OWNER SHALL PROVIDE FENCING AND OTHER SAFETY MEASURES NECESSARY IN AND AROUND ANY PROPOSED STORMWATER MANAGEMENT MEASURES (POND, WETLANDS, ETC.) OBTAINING PROPER PERMITS SHALL BE THE RESPONSIBILITY OF THE OWNER.
- RETAINING WALLS EXCEEDING 30 INCHES IN HEIGHT SHALL INCLUDE FALL PROTECTION IN THE FORM OF A HANDRAIL OR FENCING ON THE HIGH SIDE OF THE RETAINING WALL.
- PROPER COMPACTION OF ALL FILL SOILS PLACED ON SITE SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. COMPACTION SHALL BE ADEQUATE TO SUPPORT THE PROPOSED USE OF AREAS IN WHICH FILL SOILS ARE PLACED. THE CONTRACTOR SHALL HIRE A GEOTECHNICAL ENGINEER TO TEST AND VERIFY THAT COMPACTION IS ADEQUATE FOR THE PROPOSED USE OF THE AREA OF FILL PLACEMENT.
- ALL ASPECTS OF THIS PROJECT SHALL BE IN FULL COMPLIANCE WITH CURRENT ADA STANDARDS. IF THE CONTRACTOR NOTES ANY ASPECTS OF THE PROJECT WHICH ARE NOT IN COMPLIANCE, THE ENGINEER SHALL BE NOTIFIED PRIOR TO ANY FURTHER WORK BEING PERFORMED. ANY WORK PERFORMED AFTER THE CONTRACTOR NOTES SUCH A NON COMPLIANCE IS SUBJECT TO REMOVAL AND REPAIR AT THE CONTRACTOR'S EXPENSE.
- THE CONTRACTOR OR OWNER SHALL EMPLOY A GEOTECHNICAL ENGINEER TO TEST ALL EMBANKMENTS AND FILL PLACEMENT FOR PROPER COMPACTION. PROPER COMPACTION SHALL BE PER THE GEOTECHNICAL ENGINEER'S RECOMMENDATIONS OR THESE PLANS, WHICHEVER IS MORE STRINGENT. EMBANKMENTS FOR PONDS SHALL BE PLACED IN 6 INCH LOOSE LAYERS AND SHALL BE COMPACTED TO A DENSITY OF NO LESS THAN 95% OF THE STANDARD PROCTOR MAXIMUM DENSITY AT A MOISTURE CONTENT OF 4% OR TWO PERCENTAGE POINTS OF THE OPTIMUM MOISTURE CONTENT IN ACCORDANCE WITH ASTM D998. THE CONTRACTOR SHALL TAKE PHOTOGRAPHS OF THE OUTLET STRUCTURE AT ALL AT ALL PHASES OF INSTALLATION AND SHALL RETAIN WITH GEOTECHNICAL TESTING DATA. THE CONTRACTOR SHALL ALSO RETAIN ALL SHIPPING RECORDS AND SPECIFICATIONS FOR THE OUTLET STRUCTURE MATERIALS AND STRUCTURES. ALL OF THE ABOVE DATA MAY BE REQUIRED AS PART OF THE MUNICIPALITY AS-BUILT PROCESS AND SHALL BE MADE AVAILABLE TO THE ENGINEER UPON REQUEST. THE CONTRACTOR AND OWNER SHALL HAVE DOCUMENTATION OF THESE TESTS AVAILABLE UPON REQUEST.
- RETAINING WALLS SHOWN HEREIN SHALL BE DESIGNED BY A QUALIFIED PROFESSIONAL ENGINEER WITH EXPERIENCE DESIGNING RETAINING WALLS. AT LEAST 14 DAYS PRIOR TO BEGINNING CONSTRUCTION OF RETAINING WALLS, THE CONTRACTOR SHALL CONTACT THE OWNER'S GEOTECHNICAL ENGINEER TO SCHEDULE AND COORDINATE ALL APPROPRIATE INSPECTIONS, TESTING, AND VERIFICATION NECESSARY DURING RETAINING WALL CONSTRUCTION. THE GEOTECHNICAL ENGINEER SHALL PROVIDE CONTINUOUS INSPECTION, TESTING AND VERIFICATION FOR THE DURATION OF RETAINING WALL CONSTRUCTION. PROPER SCHEDULING, EXECUTION, AND RECORD KEEPING FOR ALL REQUIRED INSPECTIONS, TESTING, AND VERIFICATION SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. SUCH RECORDS SHALL BE RETAINED AND SHALL BE PROVIDED TO THE OWNER AND BASS, NIXON & KENNEDY, INC. ALL MONITORING, TESTING, AND VERIFICATION SHALL CONFORM TO THE MOST RECENT VERSION OF THE NC BUILDING CODE CHAPTER 18, SECTION 1806 OR THE WALL DESIGN ENGINEER'S SPECIFICATIONS, WHICHEVER IS MORE STRINGENT.

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer \_\_\_\_\_




LINE	BEARING	DISTANCE
L1	S 11° 10' 00" E	114.40'
L2	S 14° 20' 25" E	88.05'
L3	S 17° 25' 00" E	80.00'
L4	S 14° 35' 55" E	71.61'
L5	S 01° 08' 18" W	09.00'
L6	S 88° 34' 11" W	5.88'
L7	S 17° 00' 00" W	116.93'
L8	S 15° 01' 50" W	53.52'
L9	N 41° 07' 27" W	82.22'
L10	S 89° 51' 12" W	44.50'
L11	S 47° 03' 35" W	37.60'
L12	S 44° 51' 41" W	51.93'
L13	S 59° 25' 16" W	73.29'
L14	S 48° 09' 25" W	104.14'
L15	S 49° 16' 35" W	96.02'

- NOTES:
- EXISTING WATER MAIN TO REMAIN ACTIVE UNTIL THE PROPOSED WATER LINE IS INSTALLED, TESTED, AND READY TO BE ACTIVE.
  - SERVICES TO EXISTING BUILDINGS TO REMAIN IN PLACE THROUGHOUT CONSTRUCTION. CONTRACTOR TO VERIFY SERVICE LOCATIONS.
  - EXISTING WELLS AND SEPTIC SYSTEMS TO BE ABANDONED PER ALL WAKE COUNTY ENVIRONMENTAL SERVICES, STANDARDS & SPECIFICATIONS.



NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



**BANK**

**BASS, NIXON & KENNEDY, INC.**  
 CONSULTING ENGINEERS  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 881-4422 FAX: (919) 881-6868  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

PROGRESS	DATE	MRM	BY	DESCRIPTION
3	12-06-23	TOWN OF ROLESVILLE	MRM	REVISIONS
2	10-16-23	T.O.R. COMMENTS	MRM	REVISIONS
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM	REVISIONS

**COBBLESTONE VILLAGE**  
 MIXED USE DEVELOPMENT  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

03-19187  
 DATE: 04/19/24  
 DRAWN BY: MRM  
 CHECKED BY: MDB

SCALE: 1" = 40'

SHEET **C0.1**

NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION


NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CD'S	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM

PROGRESS DATE DRAWN BY  
 03-19-17 MRM  
 JOB NO. DATE DRAWN BY

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

**SHEET C1.1**  
 TOWN OF ROLESVILLE PROJECT NO.

- CONDITIONS OF APPROVAL:**
1. TECHNICAL REVIEW COMMITTEE APPROVAL AND ISSUANCE OF REQUIRED PERMITS FROM ALL AGENCIES MUST BE ACHIEVED AND SUBMITTED FOR REVIEW AND RECORD RETENTION PRIOR TO FINAL SIGNATURE AND APPROVAL OF THE SITE PLAN.
  2. CROSS-CONNECTION ACCESS TO ONE OF THE THREE ADJACENT PROPERTIES TO THE EAST ALONG W. YOUNG STREET (111, 113, AND 115 W. YOUNG STREET) FOR FUTURE DEVELOPMENT WILL BE PROVIDED.
  3. BEST EFFORTS WILL BE MADE FOR GREENWAY ACCESS ACROSS THE TELECOM TOWERS, LLC SITE FOR PEDESTRIAN TRAFFIC FROM OVERFLOW PARKING SITE LOCATED AT THE TERMINUS OF SCARBORO STREET IN MAIN STREET PARK.
  4. BASED UPON TESTIMONY REGARDING SHARED PARKING IN A MIXED-USE DEVELOPMENT, A 15% PARKING REDUCTION IS GRANTED RESULTING IN 467 457 REQUIRED SPACES.
  5. A MAXIMUM HEIGHT OF 60 FEET IS APPROVED PER THE BUILDING HEIGHT DESIGN ALTERNATIVE FOR THE SITE AS SHOWN ON THE SITE PLAN, PROVIDED ALL OTHER APPLICABLE STANDARDS ACCORDING TO THE LDO ARE MET.
  6. FINAL STREET DESIGN SHALL INCORPORATE A FOUNDATION OF OTHER CITY THROUGH FOR DROP-OFFS CONSISTENT WITH THE DESIGN REQUIREMENTS OF THE TOWN COMMUNITY BUILDING AS PROVIDED BY THE TOWN'S ARCHITECTURAL CONSULTANT.
  7. SUP APPROVED BY BOARD OF COMMISSIONERS ON OCTOBER 5, 2021.



**OVERALL SITE DATA**


SITE AREA	10.96 AC (477,418 SF±)
P.I.N.	1769-01-1935
ZONING DISTRICT:	TOWN CENTER (TC)
USE:	RESIDENTIAL, MIXED USE
OPEN SPACE AREA:	1.92 AC PROVIDED (1.10 AC REQUIRED, 10%)
IMPERVIOUS AREA:	7.50 AC
IMPERVIOUS AREA (%):	68%
APARTMENT MIX	
1 BEDROOM	96 UNITS
2 BEDROOM	80 UNITS
3 BEDROOM	12 UNITS
TOTAL APARTMENTS	188 UNITS
RESIDENTIAL DENSITY:	17.15 UNITS/ACRE
TOTAL RETAIL/FLEX/COMMERCIAL:	53,384 SQUARE FEET

EVENT SPACE: 0.44 ACRES / 18,976 SQUARE FEET

PARKING REQUIREMENTS PER TC DISTRICT DEVELOPMENT STANDARDS

MIXED USE RESIDENTIAL: 2.0 SPACES PER UNIT	188 x 2 = 376 SPACES REQUIRED
MIXED USE NON-RESIDENTIAL: 3 SPACES PER 1000 GSF	53,384/1000 x 3 = 161 SPACES REQUIRED
TOTAL PARKING REQUIRED/PROVIDED:	537 SPACES REQUIRED / 465 PROVIDED
5% OF ON STREET PARKING MAY BE COUNTED AS REQUIRED PARKING (27 ALLOWED / 24 PROVIDED)	
15% PARKING REDUCTION ALLOWED FOR SHARED PARKING: 537 x .85 = 457 REQUIRED / 465 PROVIDED	

BUILDING 1:	51,882 SF APARTMENTS
BUILDING 2:	11,678 SF RETAIL, 23,356 SF APARTMENTS
BUILDING 3:	8,612 SF RETAIL, 17,224 SF APARTMENTS
BUILDING 4:	10,420 SF RETAIL
BUILDING 5:	5,970 FLEX
BUILDING 6:	16,704 SF RETAIL, 33,408 SF APARTMENTS
BUILDING 7:	51,882 SF APARTMENTS
BUILDING 8:	31,710 SF APARTMENTS



CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.


City of Raleigh Development Approval  
 Raleigh Water Review Officer

ROADWAY MARKINGS TO BE IN ACCORDANCE WITH NCDOT ENCROACHMENT PERMIT E051-092-22-00547


CONTRACTOR AND DEVELOPER TO ENSURE POSITIVE DRAINAGE UNTIL IMPROVEMENTS ARE MADE BY U-6241



PROPOSED ON-STREET PARKING AS PART OF NCDOT STREETSCAPE IMPROVEMENTS PROJECT U-6241 (BY OTHERS) SHOWN IN BLUE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



04/19/24





**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 881-1122 FAX: (919) 881-8686  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CD'S	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM

PROGRESS DATE DRAWN BY  
 03-19-17 03-19-17 MRM  
**OPEN SPACE PLAN**  
 SCALE: 1" = 40'  
 CHK BY: MDB

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

SHEET **C1.2**  
 TOWN OF ROLESVILLE PROJECT NO.

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.


City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer

PROPOSED ON-STREET PARKING AS PART OF NCDOT STREETSCAPE IMPROVEMENTS PROJECT U-8241 (BY OTHERS) SHOWN IN BLUE


S. MAIN STREET - U.S. HWY 401  
 VARIABLE WIDTH PUBLIC RIGHT-OF-WAY  
 DM-1981 PG. 506

NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



04/19/24



NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer \_\_\_\_\_


**Public**  
**Water Distribution / Extension System**  
 The City of Raleigh consents to the connection and extension of the City's public water system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
 City of Raleigh  
 Public Utilities Department Permit # W-3879  
 Authorization to Construct See digital signature

**Private**  
**Sewer Collection / Extension System**  
 The City of Raleigh consents to the connection to its public sewer system and extension of the private sewer collection system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
 City of Raleigh  
 Public Utilities Department Permit # S-4962 (P)  
 Authorization to Construct See digital signature



**ATTENTION CONTRACTORS**  
 The Construction Contractor responsible for the extension of water, sewer, and/or reuse, as approved in these plans, is responsible for contacting the Public Utilities Department at (919) 996-4540 at least twenty four hours prior to beginning any of their construction.  
**Failure** to notify both City Departments in advance of beginning construction, will result in the issuance of monetary fines, and require reinstallation of any water or sewer facilities not inspected as a result of this notification failure.  
**Failure** to call for Inspection, Install a Downstream Plug, have Permitted Plans on the Jobsite, or any other Violation of City of Raleigh Standards will result in a Fine and Possible Exclusion from future work in the City of Raleigh.

- STANDARD UTILITY NOTES (as applicable):**
- All materials & construction methods shall be in accordance with City of Raleigh design standards, details & specifications (reference: CORPUD Handbook, current edition)
  - Utility separation requirements:
    - A distance of 100' shall be maintained between sanitary sewer & any private or public water supply source such as an impounded reservoir used as a source of drinking water. If adequate lateral separation cannot be achieved, ferrous sanitary sewer pipe shall be specified & installed to watertight specifications. However, the minimum separation shall not be less than 25' from a private well or 50' from a public well
    - When installing water &/or sewer mains, the horizontal separation between utilities shall be 10'. If this separation cannot be maintained due to existing conditions, the variation allowed is the water main in a separate trench with the elevation of the water main at least 18" above the top of the sewer & must be approved by the Public Utilities Director. All distances are measured from outside diameter to outside diameter
    - Where it is impossible to obtain proper separation, or anytime a sanitary sewer passes over a watermain, DIP materials or steel encasement extended 10' on each side of crossing must be specified & installed to watertight specifications
    - 5.0' minimum horizontal separation is required between all sanitary sewer & storm sewer facilities, unless DIP material is specified for sanitary sewer
    - Maintain 18" min. vertical separation at all watermain & RCP storm drain crossings; maintain 24" min. vertical separation at all sanitary sewer & RCP storm drain crossings. Where adequate separations cannot be achieved, specify DIP materials & a concrete cradle having 6" min. clearance (per CORPUD details W-41 & S-49)
    - All other underground utilities shall cross water & sewer facilities with 18" min. vertical separation required
  - Any necessary field revisions are subject to review & approval of an amended plan &/or profile by the City of Raleigh Public Utilities Department prior to construction
  - Contractor shall maintain continuous water & sewer service to existing residences & businesses throughout construction of project. Any necessary service interruptions shall be preceded by a 24 hour advance notice to the City of Raleigh Public Utilities Department
  - 3.0' minimum cover is required on all water mains & sewer force mains. 4.0' minimum cover is required on all reuse mains
  - It is the developer's responsibility to abandon or remove existing water & sewer services not being used in redevelopment of a site unless otherwise directed by the City of Raleigh Public Utilities Department. This includes abandoning tap at main & removal of service from ROW or easement per CORPUD Handbook procedure
  - Install 3/4" copper\* water services with meters located at ROW or within a 2'x2' Watertight Easement immediately adjacent. *NOTE: It is the applicant's responsibility to properly size the water service for each connection to provide adequate flow & pressure*
  - Install 4" PVC\* sewer services with cleanouts located at ROW or easement line & spaced every 75 linear feet maximum
  - Pressure reducing valves are required on all water services exceeding 80 psi; backwater valves are required on all sanitary sewer services having building drains lower than 1.0' above the next upstream manhole
  - All environmental permits applicable to the project must be obtained from NCDWQ, USACE &/or FEMA for any riparian buffer, wetland &/or floodplain impacts (respectively) prior to construction.
  - NCDOT / Railroad Encroachment Agreements are required for any utility work (including main extensions & service taps) within state or railroad ROW prior to construction
  - Grease Interceptor / Oil Water Separator sizing calculations & installation specifications shall be approved by the CORPUD IOC Program Coordinator prior to issuance of a Building Permit. Contact Tim Besley at (919) 996-2334 or [timothy.besley@raleighnc.gov](mailto:timothy.besley@raleighnc.gov) for more information
  - Cross-connection control protection devices are required based on degree of health hazard involved as listed in Appendix-B of the Rules Governing Public Water Systems in North Carolina. These guidelines are the minimum requirements. The devices shall meet American Society of Sanitary Engineering (ASSE) standards or be on the University of Southern California approval list. The devices shall be installed and tested (both initial and periodic testing thereafter) in accordance with the manufacturer's recommendations or the local cross-connection control program, whichever is more stringent. Contact Joanie Hartley at (919) 996-5923 or [joanie.hartley@raleighnc.gov](mailto:joanie.hartley@raleighnc.gov) for more information

- NOTES:**
- FOR BUILDING SEWER PLUMBING THE FURTHEST MAIN UNDER SLAB UPSET 1.5' BELOW FFE.
  - BACKFLOW PREVENTERS TO BE LOCATED INSIDE OF BUILDINGS 2 & 4.



NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 981-4422 FAX: (919) 981-8686  
 CERTIFICATION NUMBERS: NCBELS (C-011); NCBOLA (C-0267)

MRM	PROGRESS	DATE	DRAWN BY	DESCRIPTION	NO.	DATE	BY
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM				
2	10-16-23	T.O.R. COMMENTS	MRM				
1	09-21-23	CHANGES FROM 06-02-23 CDS	MRM				

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA  
 SHEET C2.1  
 UTILITY PLAN  
 SCALE: 1" = 40'  
 CHK BY: MDB

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION




Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
Raleigh Water Review Officer \_\_\_\_\_

Structure	d <sub>1</sub> (ft)	Velocity (fps)	Length (ft)	Width (ft)	Depth (in)	Type	d <sub>50</sub>
FES 1	2.00	7.4	12	6	22	Class 'B'	6" - 13"
FES 3	3.00	6.5	18	9	22	Class 'B'	6" - 13"


\* Per NYDOT Dissipator Schedule Fig.1

NOTE: STRUCTURES AD-9 & AD-10 ARE SOLID COVER



NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT




**BASS, NIXON & KENNEDY, INC.**  
CONSULTING ENGINEERS  
6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
TELEPHONE: (919)881-4422 FAX: (919)881-6868  
CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM

REVISIONS

03-19157  
JOB NO.  
03-19157  
PROGRESS  
DATE  
04/19/24  
DRAWN BY  
GRADING PLAN  
CHK BY: MDB  
SCALE: 1" = 40'  
SHEET  
C3.1  
TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA  
NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION



**CROSS-SECTION OF WET POND A-A**


NTS

**BOUAYNCY CALCULATIONS FOR RISER/BARREL**  
**COBBLESTONE VILLAGE**  
**WET POND - SCM**

Square Riser Inside Length (ft):	4.0
Riser Wall Thickness (in):	6
Pond Bottom Elevation (ft):	420.00
Riser Crest Elevation (ft):	426.50
Density of Riser Matt (lb/cf):	150.00
Pipe Inside Diameter (in):	24
Pipe Wall Thickness (in):	3
Length of Pipe Exposed (ft):	1.00
Density H2O (lb/cf):	62.40
Volume H2O Displaced by Riser (cf):	131.63
Weight H2O Displaced by Riser (lb):	8213.40
Volume H2O Displaced by Pipe (cf):	4.91
Weight H2O Displaced by Pipe (lb):	306.31
Total Uplift Force (lb):	8519.71
Weight of Riser (lb):	4,144
Weight of Pipe (lb):	265.07
Pipe/Riser Downward Force (lb):	4408.82

**Ballast Concrete:**

Minimum Factor of Safety:	1.2
Required ballast thickness (in):	37.02
Provided Ballast Thickness (in):	40
Total Downward Force (lb):	10,692
Provided Factor of Safety:	1.25




**INVERTED INTAKE DETAIL (RISER)**

NTS

**POND LEGEND - SCM**


Description	Design	As-Built
A Top of Riser	426.50 ft	
B Diameter of PVC Drawdown Pipe	4 in	
C Drawdown Orifice Opening	2.5 in	
D Drawdown Pipe Elevation / Permanent Pool	424.50 ft	
E Inside Bottom Riser Elevation	420.00 ft	
F Outlet Structure Size	4ft x 4ft	
G Top of Berm Width	10 ft	
H Top of Dam	428.00 ft	
I Ballast Thickness	40 in	
J Size of Outlet Pipe	24 in	
K Length of Outlet Pipe	18 ft	
L Slope of Outlet Pipe	2.78 %	
M Invert in Outlet Pipe	420.00 ft	
N Invert Outlet Pipe	419.80 ft	
O Top Elevation Forebay Berm	424.00 ft	
P Elevation Top of Litoral Shelf	425.00 ft	
Q Elevation Bottom of Litoral Shelf	424.00 ft	
R Slope of Litoral Shelf	6:1	
S Sediment Cleanout Elevation Forbay	422.00 ft	
T Bottom Elevation Forebay	421.00 ft	
U Sediment Cleanout Elevation Permanent Pool	421.00 ft	
V Bottom Elevation Permanent Pool	420.00 ft	
W Elevation Secondary Weir	426.20 ft	
X Width Secondary Weir	12 in	

**Special Instructions**  
 Place Drawdown pipe opposite of outlet pipe and ensure a minimum of 12" clearance between drawdown pipe opening and ground elevation to allow for proper drainage. Place secondary weir above drawdown pipe on same side of outlet structure.




**OUTLET STRUCTURE DETAIL**

NOT TO SCALE



**(IF APPLICABLE) EMERGENCY DRIP DRAIN TRASH RACK DETAIL**


NOT TO SCALE



**TRASH RACK SUBMITTAL - Aluminum Trashrack for 4x4 Box**

**TRASH RACK DETAIL**

NTS



**CONCRETE CRADLE DETAIL**

NOT TO SCALE

**CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION**

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer



04/19/24

**NO FLOODPLAINS EXIST ON-SITE**

**NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT**

PROGRESS	MRM	DATE	NO.	DESCRIPTION	BY
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM		BY
2	10-16-23	T.O.R. COMMENTS	MRM		BY
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM		BY

**CONSTRUCTION SEQUENCE - STAGE 1**

- ONCE THE EROSION AND SEDIMENT CONTROL PLAN APPROVAL AND NCGO1 CERTIFICATE OF COVERAGE ARE OBTAINED, SCHEDULE A PRECONSTRUCTION CONFERENCE WITH THE ENVIRONMENTAL CONSULTANT, OBTAIN A LAND-DISTURBING PERMIT.
- INSTALL GRAVEL CONSTRUCTION PAD, TEMPORARY DIVERSIONS, SILT FENCE, SKIMMER BASINS AND OTHER MEASURES AS SHOWN ON THE APPROVED PLAN. CLEAR ONLY AS NECESSARY TO INSTALL THESE DEVICES. SEED TEMPORARY DIVERSIONS, BERMS AND BASINS IMMEDIATELY AFTER CONSTRUCTION.
- CALL ENVIRONMENTAL CONSULTANT FOR AN ONSITE INSPECTION BY THE ENVIRONMENTAL CONSULTANT TO OBTAIN A CERTIFICATE OF COMPLIANCE.
- BEGIN CLEARING AND GRUBBING. MAINTAIN DEVICES AS NEEDED. ROUGH GRADE SITE.
- STABILIZE SITE AS AREAS ARE BROUGHT UP TO FINISH GRADE WITH VEGETATION, PAVING, DITCH LININGS, ETC. SEED AND MULCH DENUDEED AREAS PER GROUND STABILIZATION TIME FRAMES.
- STABILIZE SITE AS AREAS ARE BROUGHT UP TO FINISH GRADE WITH VEGETATION, ALLEY PAVING, DITCH LININGS, ETC. SEED AND MULCH DENUDEED AREAS PER GROUND STABILIZATION TIME FRAMES.
- CALL ENVIRONMENTAL CONSULTANT FOR AN ONSITE INSPECTION BY THE ENVIRONMENTAL CONSULTANT PRIOR TO THE REMOVAL OF SKIMMER SEDIMENT BASIN #1.
- CONTINUE TO SOIL EROSION PLAN STAGE 2 ONCE SKIMMER BASIN #1 HAS BEEN REMOVED.

NOTE: WAKE COUNTY MUST GRANT PERMISSION TO CONVERT THE SEDIMENT BASIN OVER TO THE STORMWATER USE PRIOR TO COMPLETING ANY RELATED WORK.  
TOTAL DISTURBED AREA = 11.0 AC

**DENUDED AREA = 10.96 AC**

**REQUIRED WAKE COUNTY BASIN REMOVAL AND/OR CONVERSION SEQUENCE**

- SCHEDULE A SITE MEETING WITH THE ENVIRONMENTAL CONSULTANT TO DETERMINE IF A BASIN CAN BE REMOVED OR CONVERTED TO A PERMANENT STORMWATER POND, INSTALL SILT FENCING OR OTHER TEMPORARY EROSION CONTROL MEASURES AS NEEDED PRIOR TO REMOVAL OF THE BASIN.
- UTILIZE OUTLET STRUCTURES THAT WITHDRAW WATER FROM THE SEDIMENT BASIN SURFACE FOR DRAW DOWN OF WATER IN BASIN FOR MAINTENANCE OR CLOSE OUT UNLESS INFEASIBLE. SEE REQUIREMENTS OF NCGO1 PERMIT PART I, SECTION G, ITEM (4) ENTITLED "DRAW DOWN OF SEDIMENT BASINS FOR MAINTENANCE OR CLOSE OUT" AND REFER TO WAKE COUNTY "FILTER BAG FOR Dewatering ACTIVITIES" CONSTRUCTION DETAIL.
- REMOVE BASIN(S) AND ASSOCIATED TEMPORARY DIVERSION DITCHES, IF CULVERT PIPES NEED TO BE EXTENDED, PERFORM THIS OPERATION AT THIS TIME. FINE GRADE AREA IN PREPARATION FOR SEEDING.
- PERFORM SEEDBED PREPARATION, SEED, MULCH AND ASPHALT TACK ANY RESULTING BARE AREAS IMMEDIATELY.
- INSTALL VELOCITY DISSIPATORS AND/OR LEVEL SPREADERS AS REQUIRED ON THE EROSION CONTROL PLAN.
- WHEN SITE IS FULLY STABILIZED, CALL ENVIRONMENTAL CONSULTANT FOR APPROVAL OF REMOVING REMAINING TEMPORARY EROSION CONTROL MEASURES AND ADVICE ON WHEN SITE CAN BE ISSUED A CERTIFICATE OF COMPLETION. NOTE: A MEETING SHOULD ALSO BE SCHEDULED WITH THE ENVIRONMENTAL CONSULTANT TO DETERMINE WHEN A BASIN MAY BE CONVERTED FOR STORMWATER USE. SOME MUNICIPALITIES MAY ALSO REQUIRE THIS.

**SEDIMENT BASIN SUMMARY CHART**

Sediment Basin Number	1	2	3
Drainage Area (Acres)	3.42	4.61	0.6
Orifice (ft)	(0.5)(7.22)(3.42)=12.35	(0.5)(7.22)(4.61)=16.64	(0.5)(7.22)(0.60)=2.17
Weir Size (ft)	10 x 1.5	10 x 1.5	10 x 1.5
Surface Area Required (SF)	(435)(12.35)=5,372	(435)(16.64)=7,238	(435)(2.17)=944
Volume Required (CF)	(1800)(3.42)=6,156	(1800)(4.61)=8,298	(1800)(0.60)=1,080
Dimensions (ft)	see plans	see plans	see plans
Surface Area Provided (SF)	5,400	10,640	1,584
Volume Provided (CF)	13,572	27,636	2,563
Skimmer Size	4"	4"	3"
Orifice Radius	0.5"	0.5"	0.25
Orifice Diameter	1.0"	1.25"	0.5
Drawdown Time (days)	4.62	3.98	3.74
Number of Baffles	3	3	3

**Structure**

Structure	d (ft)	Velocity (fps)	Length (ft)	Width (ft)	Depth (ft)	Type	Class	σ <sub>90</sub>
FES-1	2.00	7.4	12	6	22	Class 'B'	6" - 13"	
FES-3	3.00	6.5	18	9	22	Class 'B'	6" - 13"	
DV DITCH #1	1.25	5.3	5	4	9	Class 'A'	3" - 6"	
DV DITCH #2	1.25	5.3	5	4	9	Class 'A'	3" - 6"	
DV DITCH #3	1.25	5.3	5	4	9	Class 'A'	3" - 6"	
DV DITCH #4	1.25	5.3	5	4	9	Class 'A'	3" - 6"	
PIPE #1	1.25	5.3	5	4	9	Class 'A'	3" - 6"	
PIPE #2	1.25	5.3	5	4	9	Class 'A'	3" - 6"	

\*Per NCDOT Dissipator Schedule Fig. 1

**DITCH/CHANNEL CALCULATIONS**

DIVERSION DITCH ID	LENGTH (LF)	DA (Ac)	G10 (CFS)	SLOPE (%)	V10 (FPS)	LINER	PERMISSIBLE SHEAR STRESS (PSF)	CALCULATED SHEAR STRESS (PSF)
DV-1	296	1.02	2.34	2.00	2.01	SC150	2.00	0.78
DV-2	495	1.00	2.30	2.60	2.29	SC150	2.00	0.84
DV-3	442	0.52	1.19	1.80	0.92	SC150	1.80	0.29
DV-4	167	0.08	0.13	2.90	0.96	SC150	1.80	0.38

\*NAG = NORTH AMERICAN GREEN OR EQUIVALENT

**Skimmer Basin #1**

Skimmer Size (Inches)	Head on Skimmer (feet)	Orifice Size (1/4 inch increments)	Drawdown Time (days)
4	0.333	1.5	4.62
3	0.333	1.5	3.98
2	0.333	1.5	3.74

Required 3 to 5 days for Wake County

**Skimmer Basin #2**

Skimmer Size (Inches)	Head on Skimmer (feet)	Orifice Size (1/4 inch increments)	Drawdown Time (days)
4	0.333	1.5	3.98
3	0.333	1.5	3.74
2	0.333	1.5	3.74

Required 3 to 5 days for Wake County

**Skimmer Basin #3**


Skimmer Size (Inches)	Head on Skimmer (feet)	Orifice Size (1/4 inch increments)	Drawdown Time (days)
4	0.333	1.5	3.74
3	0.333	1.5	3.74
2	0.333	1.5	3.74

Required 3 to 5 days for Wake County

**CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION**

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
Raleigh Water Review Officer \_\_\_\_\_



- LEGEND**
- TEMP CONCRETE WASHOUT
  - TEMP LOW SPOT SILT FENCE OUTLET
  - ROCK CHECK DAM
  - TEMP CONSTRUCTION ENTRANCE
  - RIP-RAP DISSIPATOR
  - TEMP DIVERSION DITCH (LINED-SEE DETAIL)
  - TEMP SILT FENCE
  - TEMP TREE PROTECTION FENCE
  - LIMITS OF DISTURBANCE
  - SEDIMENT BASIN BAFFLE
  - TEMP TREE PROTECTION & SILT FENCE COMBO

**NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT**

SCALE IN FEET  
0 20 40 80 120 160

**BASS, NIXON & KENNEDY, INC.**  
CONSULTING ENGINEERS  
6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
TELEPHONE: (919)881-4422 FAX: (919)881-8686  
CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM

**EROSION CONTROL PLAN - STAGE 1**

PROGRESS DATE DRAWN BY: MRM  
JOB NO. 03-19187

SCALE: 1" = 40'

CHK BY: MDB

**COBBLESTONE VILLAGE MIXED USE DEVELOPMENT**  
TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

**SHEET C3.3**

TOWN OF ROLESVILLE PROJECT NO. \_\_\_\_\_

NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION



**CONSTRUCTION SEQUENCE - STAGE 2**

- BEGIN CONSTRUCTION OF ALL BUILDINGS.
  - STABILIZE SITE AS NEW DISTURBED AREAS ARE BROUGHT UP TO FINISH GRADE WITH VEGETATION, PAVING, DITCH LININGS, ETC. SEED AND MULCH DENUDATED AREAS PER GROUND STABILIZATION TIME FRAMES.
  - WHEN CONSTRUCTION OF PARKING LOTS ARE COMPLETE AND ALL AREAS ARE STABILIZED COMPLETELY, CALL ENVIRONMENTAL CONSULTANT FOR AN INSPECTION.
  - IF THE SITE IS APPROVED, REMOVE TEMPORARY DIVERSIONS, SILT FENCE, SEDIMENT BASINS, ETC., AND SEED OUT OR STABILIZE ANY RESULTING BARE AREAS. ALL REMAINING PERMANENT EROSION CONTROL DEVICES, SUCH AS VELOCITY DISSIPATORS, SHOULD NOW BE INSTALLED.
  - WHEN VEGETATION HAS BECOME ESTABLISHED, CALL FOR A FINAL SITE INSPECTION BY THE ENVIRONMENTAL CONSULTANT. OBTAIN A CERTIFICATE OF COMPLETION.
- NOTE: WAKE COUNTY MUST GRANT PERMISSION TO CONVERT THE SEDIMENT BASIN OVER TO THE STORMWATER USE PRIOR TO COMPLETING ANY RELATED WORK.
- TOTAL DISTURBED AREA = 10.96 AC
- ENVIRONMENTAL CONSULTANT: JEEVAN NEUPANE (919-819-8907)

**REQUIRED WAKE COUNTY BASIN REMOVAL AND/OR CONVERSION SEQUENCE**

- SCHEDULE A SITE MEETING WITH THE ENVIRONMENTAL CONSULTANT TO DETERMINE IF A BASIN CAN BE REMOVED OR CONVERTED TO A PERMANENT STORMWATER POND. INSTALL SILT FENCING OR OTHER TEMPORARY EROSION CONTROL MEASURES AS NEEDED PRIOR TO REMOVAL OF THE BASIN.
- UTILIZE OUTLET STRUCTURES THAT WITHDRAW WATER FROM THE SEDIMENT BASIN SURFACE FOR DRAW DOWN OF WATER IN BASIN FOR MAINTENANCE OR CLOSE OUT UNLESS INFEASIBLE. SEE REQUIREMENTS OF NCG01 PERMIT PART II, SECTION C, ITEM (4) ENTITLED "DRAW DOWN OF SEDIMENT BASIN FOR MAINTENANCE OR CLOSE OUT" AND REFER TO WAKE COUNTY "FILTER BAG FOR DEWATERING ACTIVITIES" CONSTRUCTION DETAIL.
- REMOVE BASIN(S) AND ASSOCIATED TEMPORARY DIVERSION DITCHES. IF CULVERT PIPES NEED TO BE EXTENDED, PERFORM THIS OPERATION AT THIS TIME. FINE GRADE AREA IN PREPARATION FOR SEEDING.
- PERFORM SEEDBED PREPARATION, SEED, MULCH AND ASPHALT TACK ANY RESULTING BARE AREAS IMMEDIATELY.
- INSTALL VELOCITY DISSIPATORS AND/OR LEVEL SPREADERS AS REQUIRED ON THE EROSION CONTROL PLAN.
- WHEN SITE IS FULLY STABILIZED, CALL ENVIRONMENTAL CONSULTANT FOR APPROVAL OF REMOVING REMAINING TEMPORARY EROSION CONTROL MEASURES AND ADVISE ON WHEN SITE CAN BE ISSUED A CERTIFICATE OF COMPLETION. NOTE: A MEETING SHOULD ALSO BE SCHEDULED WITH THE ENVIRONMENTAL CONSULTANT TO DETERMINE WHEN A BASIN MAY BE CONVERTED FOR STORMWATER USE. SOME MUNICIPALITIES MAY ALSO REQUIRE THIS.

**Skimmer Basin #2**

Item	Description	Value	Status
1	Drainage Area (Acres)	6.99	Okay
2	Peak Flow from 10-year Storm (cfs)	25.23	Okay
3	Required Volume (ft³)	12582	Okay
4	Required Surface Area (ft²)	10975	Okay
5	Suggested Width (ft)	74.1	Okay
6	Suggested Length (ft)	148.2	Okay
7	Trial Top Width at Spillway Invert (ft)	58	Okay
8	Trial Top Length at Spillway Invert (ft)	190	Okay
9	Trial Side Slope Ratio (Z:1)	2	Okay
10	Trial Depth (ft)	3	Okay
11	Bottom Width (ft)	48	Okay
12	Bottom Length (ft)	178	Okay
13	Bottom Area (ft²)	6188	Okay
14	Actual Volume (ft³)	28740	Okay
15	Actual Surface Area (ft²)	11020	Okay
16	Trial Weir Length (ft)	20	Okay
17	Suggested Trial Depth of Flow (ft)	0.75	Okay
18	Spillway Capacity (cfs)	39.9	Okay
19	Skimmer Size (Inches)	4	Okay
20	Head on Skimmer (feet)	0.33	Okay
21	Orifice Size (1/4 inch increments)	1.5	Okay
22	Dewatering Time (days)	4.20	Okay
23	Required 3 to 5 days for Wake County		Okay

**SEDIMENT BASIN SUMMARY CHART**

Sediment Basin Number	1	2
Drainage Area (acres)	1.74	6.99
Q10(cfs)	(0.5)(7.22)(1.74)=6.28	(0.5)(7.22)(6.99)=25.23
Weir Size (ft)	10 x 1.5	10 x 1.5
Surface Area Required (SF)	(435)(6.28)=2,732	(435)(25.23)=10,975
Volume Required (CF)	(1800)(1.74)=3,132	(1800)(6.99)=12,582
Dimensions (ft)	see plans	see plans
Surface Area Provided (SF)	2,800	11,000
Volume Provided (CF)	5,648	27,800
Skimmer Size	4"	4"
Orifice Radius	0.4"	0.75"
Orifice Diameter	0.75"	1.5"
Drawdown Time (Days)	4.18	4.2
Number of Baffles	3	3

**DITCH/CHANNEL CALCULATIONS**

DIVERSION DITCH ID	LENGTH (LF)	DA (Ac)	Q10 (CFS)	SLOPE (%)	V10 (FPS)	LINER *	PERMISSIBLE SHEAR STRESS (PSF)	CALCULATED SHEAR STRESS (PSF)
DV-1	296	1.02	2.34	2.00	2.01	SC150	2.00	0.78
DV-2	495	1.00	2.30	2.60	2.29	SC150	2.00	0.94
DV-3	442	0.52	1.19	1.80	0.92	SC150	1.80	0.29
DV-4	167	0.06	0.13	2.90	0.96	SC150	1.80	0.38

\* NAG = NORTH AMERICAN GREEN OR EQUIVALENT

**LEGEND**


- TEMP CONSTRUCTION ENTRANCE
- TEMP LOW SPOT SILT FENCE OUTLET
- TEMP INLET PROTECTION
- RIP-RAP DISSIPATOR
- TEMP SILT FENCE
- TEMP TREE PROTECTION FENCE
- LIMITS OF DISTURBANCE
- SEDIMENT BASIN BAFFLE
- TEMP TREE PROTECTION & SILT FENCE COMBO

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval

Raleigh Water Review Officer



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919)881-4422 FAX: (919)881-6868  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM










EROSION CONTROL PLAN - STAGE 2  
 SCALE: 1" = 40'  
 CHK BY: MDB

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

PROFESSIONAL SEAL  
 W. MARY D. BIZELLE  
 04/19/24

NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



**BASS, NIXON & KENNEDY, INC.**  
CONSULTING ENGINEERS  
6310 CHASE HILL ROAD, SUITE 250, RALEIGH, NC 27607  
TELEPHONE: (919) 881-1122 FAX: (919) 881-6888  
CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM

**PROGRESS** MRM  
**DATE** DRAWN BY  
**JOB NO.** EROSION CONTROL DETAILS  
**SCALE:** N.T.S.  
**CHK BY:** MDB

**COBBLESTONE VILLAGE MIXED USE DEVELOPMENT**  
TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA


**SHEET C3.5**

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_

Raleigh Water Review Officer \_\_\_\_\_



04/19/24



MRM	NO.	DATE	DESCRIPTION	BY
	3	12-08-23	TOWN OF ROLESVILLE COMMENTS	MRM
	2	10-16-23	T.O.R. COMMENTS	MRM
	1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM

PROGRESS	MRM	DATE	DRAWN BY
03-1917			

JOB NO.	03-1917
SCALE:	N.T.S.

**COBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

**SHEET C3.7**

NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION

**GROUND STABILIZATION AND MATERIALS HANDLING PRACTICES FOR COMPLIANCE WITH THE NCG01 CONSTRUCTION GENERAL PERMIT**

- Maintain vehicles and equipment to prevent discharge of fluids.
- Provide drip pans under any stored equipment.
- Identify leaks and repair as soon as feasible, or remove leaking equipment from the project.
- Collect all spent fluids, store in separate containers and properly dispose as hazardous waste (recycle when possible).
- Remove leaking vehicles and construction equipment from service until the problem has been corrected.
- Bring used fuels, lubricants, coolants, hydraulic fluids and other petroleum products to a recycling or disposal center that handles these materials.

**Temporary and Permanent Groundcover\***

SITE AREA DESCRIPTION	STABILIZATION	TIMEFRAME EXCEPTIONS
Perimeter dikes, seals, ditches, slopes	7 days	None
High Quality Water (HQW) Zones	7 days	None
Slopes steeper than 3:1	7 days	If slopes are 10' or less in length and are not steeper than 2:1, 14 days are allowed.
Slopes 3:1 or flatter	14 days	7 days for slopes greater than 50' in length.
All other areas with slopes flatter than 4:1	14 days	None, except for perimeters and HQW Zones.

\*-For Falls Lake watershed, in disturbed areas where grading activities are incomplete, provide temporary groundcover no later than seven (7) days for slopes steeper than 3:1; ten (10) days for slopes equal to or flatter than 3:1; fourteen (14) days for areas with no slope.

**GROUND STABILIZATION SPECIFICATION**  
 Stabilize the ground sufficiently so that rain will not dislodge the soil. Use one of the techniques in the table below:

Temporary Stabilization	Permanent Stabilization
<ul style="list-style-type: none"> <li>Temporary grass seed covered with straw or other mulches and tackifiers</li> <li>Hydroseeding</li> <li>Roller erosion control products with or without temporary grass seed</li> <li>Appropriately applied straw or other mulch</li> <li>Plastic sheeting</li> </ul>	<ul style="list-style-type: none"> <li>Permanent grass seed covered with straw or other mulches and tackifiers</li> <li>Geotextile fabrics such as permanent soil reinforcement matting</li> <li>Hydroseeding</li> <li>Shrubs or other permanent plantings covered with mulch</li> <li>Uniform and evenly distributed ground cover sufficient to restrain erosion</li> <li>Structural methods such as concrete, asphalt or retaining walls</li> </ul>

**POLYACRYLAMIDES (PAMS) AND FLOCCULANTS**

- Select flocculants that are appropriate for the soils being exposed during construction, selecting from the *NC DWR List of Approved PAMS/Flocculants*.
- Apply flocculants at or before the inlets to Erosion and Sediment Control Measures.
- Apply flocculants at the concentrations specified in the *NC DWR List of Approved PAMS/Flocculants* and in accordance with the manufacturer's instructions.
- Provide ponding area for containment of treated Stormwater before discharging off-site.
- Store flocculants in leak-proof containers that are kept under storm-resistant cover or surrounded by secondary containment structures.



**EQUIPMENT AND VEHICLE MAINTENANCE**

- Maintain vehicles and equipment to prevent discharge of fluids.
- Provide drip pans under any stored equipment.
- Identify leaks and repair as soon as feasible, or remove leaking equipment from the project.
- Collect all spent fluids, store in separate containers and properly dispose as hazardous waste (recycle when possible).
- Remove leaking vehicles and construction equipment from service until the problem has been corrected.
- Bring used fuels, lubricants, coolants, hydraulic fluids and other petroleum products to a recycling or disposal center that handles these materials.

**LITTER, BUILDING MATERIAL AND LAND CLEARING WASTE**

- Never bury or burn waste. Place litter and debris in approved waste containers.
- Provide a sufficient number of waste containers on site to manage the quantity of waste produced.
- Locate waste containers at least 50 feet away from storm drain inlets and surface waters unless no other alternatives are reasonably available.
- Locate waste containers on areas that do not receive substantial amounts of runoff from upland areas and does not drain directly to a storm drain, stream or wetland.
- Cover waste containers at the end of each workday and before storm events. Repair or replace damaged waste containers.
- Anchorage all lightweight items in waste containers during times of high winds.
- Empty waste containers as needed to prevent overflow.
- Dispose waste off-site at an approved disposal facility.

**PAINT AND OTHER LIQUID WASTE**


- Do not dump paint and other liquid waste into storm drains, streams or wetlands.
- Locate paint washouts at least 50 feet away from storm drain inlets and surface waters unless no other alternatives are reasonably available.
- Contain liquid wastes in a controlled area.
- Containment must be labeled, sized and placed appropriately for the needs of site.
- Prevent the discharge of soaps, solvents, detergents and other liquid wastes from construction sites.

**PORTABLE TOILETS**

- Install portable toilets on level ground, at least 50 feet away from storm drains, streams or wetlands unless there is no alternative reasonably available. If 50 foot offset is not attainable, provide relocation of portable toilet behind silt fence or place on a gravel pad and surround with sand bags.
- Provide staking or anchoring of portable toilets during periods of high winds or in high foot traffic areas.
- Monitor portable toilets for leaking and properly dispose of any leaked material. Utilize a licensed sanitary waste hauler to remove leaking portable toilets and replace with properly operating unit.

**EARTHEN STOCKPILE MANAGEMENT**

- Show stockpile locations on plans. Locate earthen-material stockpile areas at least 50 feet away from storm drain inlets, sediment basins, perimeter sediment controls and surface waters unless it can be shown no other alternatives are reasonably available.
- Protect stockpile with silt fence installed along toe of slope with a minimum offset of five feet from the toe of stockpile.
- Provide stable stone access point when feasible.
- Stabilize stockpile within the timeframes provided on this sheet and in accordance with the approved plan and any additional requirements. Soil stabilization is defined as vegetative, physical or chemical coverage techniques that will restrain accelerated erosion on disturbed soils for temporary or permanent control needs.



**CONCRETE WASHOUTS**

- Do not discharge concrete or cement slurry from the site.
- Dispose of, or recycle settled, hardened concrete residue in accordance with local and state solid waste regulations and at an approved facility.
- Manage washout from mortar mixers in accordance with the above item and in addition place the mixer and associated materials on impervious barrier and within lot perimeter silt fence.
- Install temporary concrete washouts per local requirements, where applicable. If an alternate method or product is to be used, contact your approval authority for review and approval. If local standard details are not available, use one of the types of temporary concrete washouts provided on this detail.
- Do not use concrete washouts for dewatering or storing defective curb or sidewalk sections. Stormwater accumulated within the washout may not be pumped into or discharged to the storm drain system or receiving surface waters. Liquid waste must be pumped out and removed from project.
- Locate washouts at least 50 feet from storm drain inlets and surface waters unless it can be shown that no other alternatives are reasonably available. At a minimum, install protection of storm drain inlet(s) closest to the washout which could receive spills or overflow.
- Locate washouts in an easily accessible area, on level ground and install a stone entrance pad in front of the washout. Additional controls may be required by the approving authority.
- Install at least one sign directing concrete trucks to the washout within the project limits. Post signage on the washout itself to identify this location.
- Remove leavings from the washout when at approximately 75% capacity to limit overflow events. Replace the tarp, sand bags or other temporary structural components when no longer functional. When utilizing alternative or proprietary products, follow manufacturer's instructions.
- At the completion of the concrete work, remove remaining leavings and dispose of in an approved disposal facility. Fill pit, if applicable, and stabilize any disturbance caused by removal of washout.

**HERBICIDES, PESTICIDES AND RODENTICIDES**

- Store and apply herbicides, pesticides and rodenticides in accordance with label restrictions.
- Store herbicides, pesticides and rodenticides in their original containers with the label, which lists directions for use, ingredients and first aid steps in case of accidental poisoning.
- Do not store herbicides, pesticides and rodenticides in areas where flooding is possible or where they may spill or leak into wells, stormwater drains, ground water or surface water. If a spill occurs, clean area immediately.
- Do not stockpile these materials onsite.

**HAZARDOUS AND TOXIC WASTE**

- Create designated hazardous waste collection areas on-site.
- Place hazardous waste containers under cover or in secondary containment.
- Do not store hazardous chemicals, drums or bagged materials directly on the ground.

**NCG01 GROUND STABILIZATION AND MATERIALS HANDLING EFFECTIVE: 03/01/19**

**PART III SELF-INSPECTION, RECORDKEEPING AND REPORTING**

**SECTION A: SELF-INSPECTION**  
 Self-inspections are required during normal business hours in accordance with the table below. When adverse weather or site conditions would cause the safety of the inspection personnel to be in jeopardy, the inspection may be delayed until the next business day on which it is safe to perform the inspection. In addition, when a storm event of equal to or greater than 1.0 inch occurs outside of normal business hours, the self-inspection shall be performed upon the commencement of the next business day. Any time when inspections were delayed shall be noted in the Inspection Record.

Inspect	Frequency (during normal business hours)	Inspection records must include:
(1) Rain gauge maintained in good working order	Daily	Daily rainfall amounts. If no daily rain gauge observations are made during weekend or holiday periods, and no individual-day rainfall information is available, record the cumulative rain measurement for those un-attended days (note this will determine if a site inspection is needed). Days on which no rainfall occurred shall be recorded as "zero." The permittee may use another rain-monitoring device approved by the Division.
(2) E&S Measures	At least once per 7 calendar days and within 24 hours of a rain event ≥ 1.0 inch in 24 hours	1. Identification of the measures inspected, 2. Date and time of the inspection, 3. Name of the person performing the inspection, 4. Indication of whether the measures were operating properly, 5. Description of maintenance needs for the measure, 6. Description, evidence, and date of corrective actions taken.
(3) Stormwater discharge outfalls (DOCs)	At least once per 7 calendar days and within 24 hours of a rain event ≥ 1.0 inch in 24 hours	1. Identification of the discharge outfalls inspected, 2. Date and time of the inspection, 3. Name of the person performing the inspection, 4. Evidence of indicators of stormwater pollution such as oil sheen, floating or suspended solids or discoloration, 5. Indication of visible sediment leaving the site, 6. Description, evidence, and date of corrective actions taken.
(4) Perimeter of site	At least once per 7 calendar days and within 24 hours of a rain event ≥ 1.0 inch in 24 hours	If visible sedimentation is found outside site limits, then a record of the following shall be made: 1. Actions taken to clean up or stabilize the sediment that has left the site limits, 2. Description, evidence, and date of corrective actions taken, and 3. An explanation as to the actions taken to control future releases.
(5) Streams or wetlands on-site (where accessible)	At least once per 7 calendar days and within 24 hours of a rain event ≥ 1.0 inch in 24 hours	If the stream or wetland has increased visible sedimentation or a stream has visible increased turbidity from the construction activity, then a record of the following shall be made: 1. Description, evidence and date of corrective actions taken, and 2. Records of the required reports to the appropriate Division Regional Office per Part III, Section C, Item 2(a) of this permit.
(6) Ground stabilization measures	After each phase of grading	1. The plan for E&S measures, clearing and grubbing, installation of storm control measures, and date of corrective actions taken, and 2. Documentation that the required ground stabilization measures have been provided within the required timeframe or an assurance that they will be provided as soon as possible.

NOTE: The rain inspection resets the required 7 calendar day inspection requirement.

**PART III SELF-INSPECTION, RECORDKEEPING AND REPORTING**

**SECTION B: RECORDKEEPING**  
**1. E&S Plan Documentation**  
 The approved E&S plan as well as any approved deviation shall be kept on the site. The approved E&S plan must be kept up-to-date throughout the coverage under this permit. The following items pertaining to the E&S plan shall be kept on site and available for inspection at all times during normal business hours.

Item to Document	Documentation Requirements
(a) Each E&S measure has been installed and does not significantly deviate from the locations, dimensions and relative elevations shown on the approved E&S plan.	Initial and date each E&S measure on a copy of the approved E&S plan or complete, date and sign an inspection report that lists each E&S measure shown on the approved E&S plan. This documentation is required upon the initial installation of the E&S measures or if the E&S measures are modified after initial installation.
(b) A phase of grading has been completed.	Initial and date a copy of the approved E&S plan or complete, date and sign an inspection report to indicate completion of the construction phase.
(c) Ground cover is located and installed in accordance with the approved E&S plan.	Initial and date a copy of the approved E&S plan or complete, date and sign an inspection report to indicate compliance with approved ground cover specifications.
(d) The maintenance and repair requirements for all E&S measures	Complete, date and sign an inspection report.
(e) Corrective actions have been taken to E&S measures.	Initial and date a copy of the approved E&S plan or complete, date and sign an inspection report to indicate the completion of the corrective action.

**2. Additional Documentation to be Kept on Site**  
 In addition to the E&S plan documents above, the following items shall be kept on the site and available for inspectors at all times during normal business hours, unless the Division provides a site-specific exemption based on unique site conditions that make this requirement not practical:

- This General Permit as well as the Certificate of Coverage, after it is received.
- Records of inspections made during the previous twelve months. The permittee shall record the required observations on the Inspection Record Form provided by the Division or a similar inspection form that includes all the required elements. Use of electronically-available records in lieu of the required paper copies will be allowed if shown to provide equal access and utility as the hard-copy records.

**3. Documentation to be Retained for Three Years**  
 All data used to complete the e-NOI and all inspection records shall be maintained for a period of three years after project completion and made available upon request. (40 CFR 122.41)

**PART III SELF-INSPECTION, RECORDKEEPING AND REPORTING**

**SECTION C: REPORTING**

**1. Occurrences that Must be Reported**  
 Permittees shall report the following occurrences:

- Visible sediment deposition in a stream or wetland.
- Oil spills if:
  - They are 25 gallons or more,
  - They are less than 25 gallons but cannot be cleaned up within 24 hours,
  - They cause sheen on surface waters (regardless of volume), or
  - They are within 100 feet of surface waters (regardless of volume).
- Releases of hazardous substances in excess of reportable quantities under Section 311 of the Clean Water Act (Ref: 40 CFR 110.3 and 40 CFR 117.3) or Section 102 of CERCLA (Ref: 40 CFR 302.4) or G.S. 143-215.85.
- Anticipated bypasses and unanticipated bypasses.
- Noncompliance with the conditions of this permit that may endanger health or the environment.

**2. Reporting Timeframes and Other Requirements**  
 After a permittee becomes aware of an occurrence that must be reported, he shall contact the appropriate Division regional office within the timeframes and in accordance with the other requirements listed below. Occurrences outside normal business hours may also be reported to the Department's Environmental Emergency Center personnel at (800) 858-0368.

Occurrence	Reporting Timeframes (After Discovery) and Other Requirements
(a) Visible sediment deposition in a stream or wetland	<ul style="list-style-type: none"> <li><b>Within 24 hours</b>, an oral or electronic notification.</li> <li><b>Within 7 calendar days</b>, a report that contains a description of the sediment and actions taken to address the cause of the deposition. Division staff may waive the requirement for a written report on a case-by-case basis.</li> <li>If the stream is named on the <a href="#">NC 303(d) list</a> as impaired for sediment-related causes, the permittee may be required to perform additional monitoring, inspections or apply more stringent practices if staff determine that additional requirements are needed to assure compliance with the federal or state impaired-waters conditions.</li> </ul>
(b) Oil spills and release of hazardous substances per Item 1(b)-(c) above	<ul style="list-style-type: none"> <li><b>Within 24 hours</b>, an oral or electronic notification. The notification shall include information about the date, time, nature, volume and location of the spill or release.</li> <li><b>A report at least ten days before the date of the bypass, if possible.</b> The report shall include an evaluation of the anticipated quality and effect of the bypass.</li> </ul>
(c) Anticipated bypasses (40 CFR 122.41(m)(3))	<ul style="list-style-type: none"> <li><b>Within 24 hours</b>, an oral or electronic notification.</li> <li><b>Within 7 calendar days</b>, a report that includes an evaluation of the quality and effect of the bypass.</li> </ul>
(d) Unanticipated bypasses (40 CFR 122.41(m)(3))	<ul style="list-style-type: none"> <li><b>Within 24 hours</b>, an oral or electronic notification.</li> <li><b>Within 7 calendar days</b>, a report that contains a description of the noncompliance, and its causes; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time noncompliance is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance. (40 CFR 122.41(j)(6)).</li> <li>Division staff may waive the requirement for a written report on a case-by-case basis.</li> </ul>

**PART II, SECTION G, ITEM (4) DRAW DOWN OF SEDIMENT BASINS FOR MAINTENANCE OR CLOSE OUT**

Sediment basins and traps that receive runoff from drainage areas of one acre or more shall use outlet structures that withdraw water from the surface when these devices need to be drawn down for maintenance or close out unless this is infeasible. The circumstances in which it is not feasible to withdraw water from the surface shall be rare (for example, times with extended cold weather). Non-surface withdrawals from sediment basins shall be allowed only when all of the following criteria have been met:

- The E&S plan authority has been provided with documentation of the non-surface withdrawal and the specific time periods or conditions in which it will occur. The non-surface withdrawal shall not commence until the E&S plan authority has approved these items,
- The non-surface withdrawal has been reported as an anticipated bypass in accordance with Part III, Section C, Item 2(c) and (d) of this permit,
- Dewatering discharges are treated with controls to minimize discharges of pollutants from stormwater that is removed from the sediment basin. Examples of appropriate controls include properly sited, designed and maintained dewatering tanks, weir tanks, and filtration systems,
- Vegetated, upland areas of the sites or a properly designed stone pad is used to the extent feasible at the outlet of the dewatering treatment devices described in Item (c) above,
- Velocity dissipation devices such as check dams, and riprap are provided at the discharge points of all dewatering devices, and
- Sediment removed from the dewatering treatment devices described in Item (c) above is disposed of in a manner that does not cause deposition of sediment into waters of the United States.

**CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION**

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must be used in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer

04/19/24

**NCG01 SELF-INSPECTION, RECORDKEEPING AND REPORTING EFFECTIVE: 04/01/19**

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_

Raleigh Water Review Officer

STORMDRAINAGE PIPE TABLE							
U.S. STRUCTURE	D.S. STRUCTURE	U.S. INVERT	D.S. INVERT	LENGTH	DIAMETER	MATERIAL	SLOPE
		-2.17	-2.50	47.47	12	RCP	0.70%
		-2.17	-2.53	51.86	12	RCP	0.70%
2	1	420.00	419.80	18.80	24	HDPE	1.06%
4	3	421.26	421.00	43.91	36	HDPE	0.60%
5	4	422.04	421.36	113.45	36	HDPE	0.60%
5A	5	422.79	422.14	107.85	36	HDPE	0.60%
5B	5A	423.20	422.79	68.66	36	HDPE	0.60%
6	5B	423.35	423.20	25.31	36	HDPE	0.60%
7	6	423.62	423.45	28.04	36	HDPE	0.60%
8	7	425.82	424.94	88.24	24	HDPE	1.00%
9	8	426.82	425.92	90.21	24	HDPE	1.00%
10	9	427.59	426.92	67.14	24	HDPE	1.00%

STORMDRAINAGE PIPE TABLE							
U.S. STRUCTURE	D.S. STRUCTURE	U.S. INVERT	D.S. INVERT	LENGTH	DIAMETER	MATERIAL	SLOPE
11	10	428.63	427.69	93.66	18	HDPE	1.00%
12	11	429.65	428.73	91.93	18	HDPE	1.00%
13	12	430.39	429.75	63.96	15	HDPE	1.00%
14	13	430.75	430.49	25.95	15	HDPE	1.00%
15	5	424.10	423.05	105.41	15	HDPE	1.00%
16	7	424.61	423.72	147.77	24	HDPE	0.60%
17	16	425.41	424.71	116.44	24	HDPE	0.60%
18	17	428.85	427.77	107.92	15	HDPE	1.00%
19	18	431.57	430.69	88.39	15	HDPE	1.00%
20	19	432.50	431.67	83.01	15	HDPE	1.00%
21	6	424.22	423.45	76.89	24	HDPE	1.00%
22	21	424.60	424.32	27.60	15	HDPE	1.00%

STORMDRAINAGE PIPE TABLE							
U.S. STRUCTURE	D.S. STRUCTURE	U.S. INVERT	D.S. INVERT	LENGTH	DIAMETER	MATERIAL	SLOPE
23	22	426.78	424.70	207.76	15	HDPE	1.00%
24	10	432.22	430.86	90.55	15	HDPE	1.50%
27	28	436.27	435.41	57.44	15	HDPE	1.50%
28	35A	435.31	434.76	65.53	15	HDPE	0.84%
29	22	425.05	424.70	34.83	15	HDPE	1.00%
30	17	426.34	425.51	137.91	18	HDPE	0.60%
30A	30B	426.96	426.66	60.86	15	HDPE	0.50%
30B	30	426.46	426.34	23.19	15	HDPE	0.50%
31	18	429.82	428.95	87.08	15	HDPE	1.00%
31A	31	430.67	429.82	85.13	12	HDPE	1.00%
32	9	429.50	428.60	90.23	15	HDPE	1.00%
33	24	432.43	432.32	11.23	15	HDPE	1.00%

STORMDRAINAGE PIPE TABLE							
U.S. STRUCTURE	D.S. STRUCTURE	U.S. INVERT	D.S. INVERT	LENGTH	DIAMETER	MATERIAL	SLOPE
34	17	428.09	427.77	32.09	12	HDPE	1.00%
35	33	434.14	432.53	160.60	15	HDPE	1.00%
35A	35	434.76	434.24	48.13	15	HDPE	1.07%
45 DEG - 1	AD-11	435.90	435.85	5.30	8	HDPE	1.00%
45 DEG - 2	45 DEG - 1	436.10	435.90	19.79	8	HDPE	1.00%
45 DEG - 3	28	435.82	435.41	40.88	8	HDPE	1.00%
45 DEG - 4	45 DEG - 3	436.55	435.82	73.37	8	HDPE	1.00%
45 DEG - 5	45 DEG - 4	436.68	436.55	12.62	8	HDPE	1.00%
195	45 DEG - 2	437.16	436.10	105.91	8	HDPE	1.00%
196	45 DEG - 5	437.05	436.68	37.10	8	HDPE	1.00%
AD-1	27	438.35	437.59	75.93	12	HDPE	1.00%
AD-2	20	434.02	432.70	131.56	12	HDPE	1.00%

STORMDRAINAGE PIPE TABLE							
U.S. STRUCTURE	D.S. STRUCTURE	U.S. INVERT	D.S. INVERT	LENGTH	DIAMETER	MATERIAL	SLOPE
AD-3	AD-2	433.18	432.13	105.35	12	HDPE	1.00%
AD-4	AD-3	433.92	433.38	54.03	12	HDPE	1.00%
AD-5	AD-4	435.05	434.62	43.08	12	HDPE	1.00%
AD-6	33	432.68	432.53	14.61	12	HDPE	1.00%
AD-7	23	428.09	426.98	111.06	12	HDPE	1.00%
AD-9	35	434.37	434.24	13.34	12	RCP	1.00%
AD-10	AD-9	434.79	434.57	21.82	12	RCP	1.00%
AD-11	AD-10	435.65	434.99	66.36	12	RCP	1.00%
AD-12	AD-11	436.15	435.85	29.90	12	RCP	1.00%

STORMDRAINAGE STRUCTURE TABLE		
STRUCTURE NAME	INSERTION RIM ELEVATION (FLOWLINE)	STRUCTURE TYPE
1	422.45 INV. IN= 419.80 (2)	24" FES
2	426.50 INV. OUT= 420.00 (1)	RISER
3	424.83 INV. IN= 421.00 (4)	36" FES
4	428.06 INV. IN= 421.36 (5) INV. OUT= 421.26 (3)	NCDOT CURB INLET
5	429.40 INV. IN= 422.14 (5A) INV. IN= 423.05 (15) INV. OUT= 422.04 (4)	NCDOT CURB INLET
5A	429.50 INV. IN= 422.79 (5B) INV. OUT= 422.79 (5)	NCDOT CURB INLET
5B	429.00 INV. IN= 423.20 (6) INV. OUT= 423.20 (5A)	HDPE YARD INLET
6	430.50 INV. IN= 423.45 (7) INV. IN= 423.45 (21) INV. OUT= 423.35 (5B)	NCDOT CURB INLET
7	430.65 INV. IN= 424.94 (8) INV. IN= 423.72 (16) INV. OUT= 423.62 (6)	NCDOT CURB INLET
8	433.45 INV. IN= 425.92 (9) INV. OUT= 425.82 (7)	NCDOT CURB INLET
9	433.25 INV. IN= 426.92 (10) INV. IN= 428.60 (32) INV. OUT= 426.82 (8)	NCDOT CURB INLET
10	436.67 INV. IN= 427.69 (11) INV. IN= 430.66 (24) INV. OUT= 427.59 (9)	HDPE YARD INLET
11	437.44 INV. IN= 428.73 (12) INV. OUT= 428.63 (10)	HDPE YARD INLET
12	436.50 INV. IN= 429.75 (13) INV. OUT= 429.65 (11)	HDPE YARD INLET
13	435.50 INV. IN= 430.49 (14) INV. OUT= 430.39 (12)	NCDOT CURB INLET
14	435.50 INV. OUT= 430.75 (13)	NCDOT CURB INLET
15	428.50 INV. OUT= 424.10 (5)	HDPE YARD INLET
16	432.50 INV. IN= 424.71 (17) INV. OUT= 424.61 (7)	NCDOT CURB INLET

STORMDRAINAGE STRUCTURE TABLE		
STRUCTURE NAME	INSERTION RIM ELEVATION (FLOWLINE)	STRUCTURE TYPE
17	434.01 INV. IN= 427.77 (18) INV. IN= 425.51 (30) INV. IN= 427.77 (34) INV. OUT= 425.41 (16)	NCDOT CURB INLET
18	435.60 INV. IN= 430.69 (19) INV. IN= 428.95 (31) INV. OUT= 428.85 (17)	NCDOT CURB INLET
19	437.52 INV. IN= 431.67 (20) INV. OUT= 431.57 (18)	NCDOT CURB INLET
20	438.60 INV. IN= 432.70 (AD-2) INV. OUT= 432.50 (19)	NCDOT CURB INLET
21	431.60 INV. IN= 424.32 (22) INV. OUT= 424.22 (6)	HDPE YARD INLET
22	431.50 INV. IN= 424.70 (23) INV. IN= 424.70 (29) INV. OUT= 424.60 (21)	NCDOT CURB INLET
23	435.80 INV. IN= 426.98 (AD-7) INV. OUT= 426.78 (22)	NCDOT CURB INLET
24	437.18 INV. IN= 432.32 (33) INV. OUT= 432.22 (10)	HDPE YARD INLET
27	440.00 INV. IN= 437.59 (AD-1) INV. OUT= 436.27 (28)	HDPE YARD INLET
28	441.50 INV. IN= 435.41 (27) INV. IN= 435.41 (45 DEG - 3) INV. OUT= 435.31 (35A)	HDPE YARD INLET
29	428.50 INV. OUT= 425.05 (22)	HDPE YARD INLET
30	430.50 INV. IN= 426.34 (30B) INV. OUT= 426.34 (17)	NCDOT CURB INLET
30A	430.50 INV. OUT= 426.96 (30B)	HDPE YARD INLET
30B	430.00 INV. IN= 426.66 (30A) INV. OUT= 426.46 (30)	YARD INLET
31	434.10 INV. IN= 429.82 (31A) INV. OUT= 429.82 (18)	NCDOT CURB INLET
31A	433.00 INV. OUT= 430.67 (31)	HDPE YARD INLET
32	435.52 INV. OUT= 429.50 (9)	NCDOT CURB INLET
33	437.50 INV. IN= 432.53 (35) INV. IN= 432.53 (AD-6) INV. OUT= 432.43 (24)	NCDOT CURB INLET

STORMDRAINAGE STRUCTURE TABLE		
STRUCTURE NAME	INSERTION RIM ELEVATION (FLOWLINE)	STRUCTURE TYPE
34	431.00 INV. OUT= 428.09 (17)	HDPE YARD INLET
35	441.00 INV. IN= 434.24 (35A) INV. IN= 434.24 (AD-9) INV. OUT= 434.14 (33)	HDPE YARD INLET
35A	441.00 INV. IN= 434.76 (28) INV. OUT= 434.76 (35)	HDPE YARD INLET
45 DEG - 1	436.47 INV. IN= 435.90 (45 DEG - 2) INV. OUT= 435.90 (AD-11)	NULL STRUCTURE
45 DEG - 2	436.67 INV. IN= 436.10 (195) INV. OUT= 436.10 (45 DEG - 1)	NULL STRUCTURE
45 DEG - 3	436.39 INV. IN= 435.82 (45 DEG - 4) INV. OUT= 435.82 (28)	NULL STRUCTURE
45 DEG - 4	437.12 INV. IN= 436.55 (45 DEG - 5) INV. OUT= 436.55 (45 DEG - 3)	NULL STRUCTURE
45 DEG - 5	437.25 INV. IN= 436.68 (196) INV. OUT= 436.68 (45 DEG - 4)	NULL STRUCTURE
195	437.73 INV. OUT= 437.16 (45 DEG - 2)	NULL STRUCTURE
196	437.62 INV. OUT= 437.05 (45 DEG - 5)	NULL STRUCTURE
AD-1	441.40 INV. OUT= 438.35 (27)	HDPE YARD INLET
AD-2	441.05 INV. IN= 432.13 (AD-3) INV. OUT= 434.02 (20)	HDPE YARD INLET
AD-3	440.50 INV. IN= 433.38 (AD-4) INV. OUT= 433.18 (AD-2)	HDPE YARD INLET
AD-4	440.50 INV. IN= 434.62 (AD-5) INV. OUT= 433.92 (AD-3)	HDPE YARD INLET
AD-5	440.50 INV. OUT= 435.05 (AD-4)	HDPE YARD INLET
AD-6	438.00 INV. OUT= 432.68 (33)	HDPE YARD INLET
AD-7	435.50 INV. OUT= 428.09 (23)	HDPE YARD INLET
AD-9	440.91 INV. IN= 434.57 (AD-10) INV. OUT= 434.37 (35)	HDPE YARD INLET

STORMDRAINAGE STRUCTURE TABLE		
STRUCTURE NAME	INSERTION RIM ELEVATION (FLOWLINE)	STRUCTURE TYPE
AD-10	440.83 INV. IN= 434.99 (AD-11) INV. OUT= 434.79 (AD-9)	HDPE YARD INLET
AD-11	441.33 INV. IN= 435.85 (45 DEG - 1) INV. IN= 435.85 (AD-12) INV. OUT= 435.65 (AD-10)	HDPE YARD INLET
AD-12	440.50 INV. OUT= 436.15 (AD-11)	HDPE YARD INLET

NOTE: ALL STORM ITEMS SHALL BE AS-BUILT PER THE TOWN UDO SECTION 7.5.5, WHICH SPECIFIES REQUIREMENTS AS-BUILTS FOR STORM.



BASS, NIXON & KENNEDY, INC.  
CONSULTING ENGINEERS  
6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
TELEPHONE: (919)881-1122 FAX: (919)881-8686  
CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM

PROGRESS	MRM	DATE	DRAWN BY
03-19-17			



COBBLESTONE VILLAGE MIXED USE DEVELOPMENT  
TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

SHEET C3.8



04/19/24

NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION



**Public**  
**Water Distribution / Extension System**  
 The City of Raleigh consents to the connection and extension of the City's public water system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
 City of Raleigh  
 Public Utilities Department Permit # W-3879  
 Authorization to Construct See digital signature

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION  
 Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer \_\_\_\_\_



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919)881-1422 FAX: (919)881-8686  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)



NO.	DATE	DESCRIPTION	BY
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM
2	10-16-23	T.O.R. COMMENTS	MRM
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM

PROGRESS	MRM	DATE	DRAWN BY
03-19157			

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

SHEET **C4.1**


**PUBLIC WATERLINE PROFILE**



04/19/24

NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



**Private Sewer Collection / Extension System**  
 The City of Raleigh consents to the connection to its public sewer system and extension of the private sewer collection system as shown on this plan. The material and construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.  
 City of Raleigh  
 Public Utilities Department Permit # S-4962 (P)  
 Authorization to Construct See digital signature

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION  
 Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.  
 City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer \_\_\_\_\_



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919)851-1422 FAX: (919)851-8686  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)



NO.	DATE	DESCRIPTION	MRM	BY
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM	MRM
2	10-16-23	T.O.R. COMMENTS	MRM	MRM
1	09-21-23	CHANGES FROM 06-02-22 CD'S	MRM	MRM

PROGRESS	MRM	DATE	DRAWN BY
03-19157	MRM		

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

SHEET  
**C4.2**

**SANITARY SEWER PROFILE**







NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT



**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919)851-1122 FAX: (919)851-8888  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)



PROGRESS	MRM	DATE	DESCRIPTION
03-19-17	PROGRESS		
	DATE		
	MRM		
	NO.		
	DATE		
	DESCRIPTION		
	BY		

**COBBLESTONE VILLAGE MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

**SHEET C4.3**

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer




**NO FLOODPLAINS EXIST ON-SITE**

**NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT**





NO.	DATE	DESCRIPTION	BY
1	5-28-21	PER TOR COMMENTS	GW
2	04-20-22	PER TOR COMMENTS	GW
3	05-12-22	PER TOR COMMENTS	GW
4	12-08-23	PER TOR COMMENTS	GW
5	02-19-24	PER TOR COMMENTS	GW

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA  
 SCALE: 1" = 40'  
 CHK BY: GPW



**PLANT LIST**

KEY	SCIENTIFIC NAME	COMMON NAME	QUAN.	CAL	HT	ROOT	USE
<b>CANOPY TREES</b>							
AF	<i>Acer freemanii</i>	Freeman Maple	32	2.5"	8'	B&B	Buffer/VUA
AR	<i>Acer rubrum</i> 'Brandywine'	Brandywine Red Maple	26	2.5"	8'	B&B	VUA
JV	<i>Juniperus virginiana</i>	Eastern Red Cedar	29	2.5"	8'	B&B	Buffer/VUA
QN	<i>Quercus nuttallii</i>	Nuttall Oak	18	2.5"	8'	B&B	Street Tree
UP	<i>Ulmus parvifolia</i> 'Allee'	Allee Elm	28	2.5"	8'	B&B	VUA
<b>UNDERSTORY TREES</b>							
LI	<i>Lagerstroemia indica</i> 'Tonto'	Crepe Myrtle	6	1.5"	6'	B&B	Street
MJ	<i>Magnolia x Jane</i>	Jane Magnolia	2	1.5"	6'	B&B	
<b>SHRUBS</b>							
AL	<i>Azalea Encore</i> ® 'Autumn Lilac'	Autumn Lilac Azalea	23		24"	CONT.	
AR	<i>Azalea Encore</i> ® 'Autumn Royalty'	Autumn Royalty Azalea	38		24"	CONT.	
AS	<i>Azalea Encore</i> ® 'Autumn Sangria'	Autumn Sangria Azalea	21		24"	CONT.	
CB	<i>Calamagrostis brachytricha</i>	Korean Feather Reed Grass	56		12"	FLAT	
CR	<i>Camellia sasanqua</i> 'Autumn Rocket'	Autumn Rocket Camellia	15		24"	CONT.	
CM	<i>Camellia sasanqua</i> 'Mine-no-Yuki'	Mine-no-Yuki Camellia	10		24"	CONT.	
CO	<i>Camellia sasanqua</i> 'October Magic'® Carpet™	October Magic Carpet Camellia	72		24"	CONT.	
CD	<i>Camellia sasanqua</i> 'October Magic'® Dawn™	October Magic Dawn Camellia	7		24"	CONT.	
CW	<i>Camellia sasanqua</i> 'October Magic'® White Shi-Shi™	White Shi-Shi Camellia	47		24"	CONT.	
CG	<i>Camellia sasanqua</i> 'Shishi Gashira'	Shishi Gashira Camellia	3		24"	CONT.	
CJ	<i>Cleyera japonica</i>	Japanese Cleyera	98		24"	CONT.	Buffer
DO	<i>Daphne odora</i> 'Aureomarginata'	Variiegated Winter Daphne	22		24"	CONT.	
DJ	<i>Distylium</i> 'Green Wave'	Green Wave Distylium	30		24"	CONT.	VUA
FG	<i>Fatsia japonica</i>	Japanese Fatsia	6		36"	CONT.	
IC	<i>Ilex crenata</i> 'Sky Pencil'	Sky Pencil Holly	6		36"	CONT.	Dumpster
IC	<i>Ilex crenata</i> 'Chesapeake'	Chesapeake Holly	10		24"	CONT.	VUA Screen
ICG	<i>Ilex crenata</i> 'Green Lustre'	Green Lustre Japanese Holly	71		24"	CONT.	Buffer
JC	<i>Juniperus chinensis</i> 'Saybrook Gold'	Saybrook Gold Juniper	44		24"	CONT.	VUA Screen
LI	<i>Ligustrum japonicum</i>	Wax Ligustrum	106		24"	CONT.	Buffer
LC	<i>Loropetalum chinense</i> 'Danama'	Danama Loropetalum	36		24"	CONT.	VUA Screen
LD	<i>Loropetalum chinense</i> 'Purple Daydream'	Purple Daydream Loropetalum	94		24"	CONT.	
ME	<i>Mahonia eurybracteata</i> 'Soft Caress'	Soft Caress Mahonia	3		24"	CONT.	
OF	<i>Osmanthus fragrans</i>	Fragrant Tea Olive	59		24"	CONT.	Buffer/Screen
OA	<i>Osmanthus fragrans aurantiacus</i> 'Apricot Echo'	Apricot Echo Fragrant Tea Olive	4		36"	CONT.	
SA	<i>Sesleria autumnalis</i>	Autumn Moor Grass	52		12"	FLAT	
VML	<i>Viburnum x Moonlit Lace</i> '	Moonlit Lace Viburnum	108		24"	CONT.	Buffer
<b>GROUNDCOVERS</b>							
CP	<i>Carex pensylvanica</i>	Pennsylvania Sedge	344		12"	FLAT	
	Ornamental Grass Mix				12"	FLAT	
	Wildflower Mix					SEED	




NORTH CAROLINA  
 REGISTERED LANDSCAPE ARCHITECT  
 #823  
 [Signature]  
 04-19-24

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION  
 Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.


City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer \_\_\_\_\_

**NO FLOODPLAINS EXIST ON-SITE**


**NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT**




SHEET  
**L1.1**




**1 MASONRY SEAT WALL WITH STONE VENEER**  
SCALE: 3/4" = 1'-0"



**2 MASONRY WALL WITH STONE VENEER**  
SCALE: 3/4" = 1'-0"



**TYPICAL TREE PLANTING**  
NOT TO SCALE



**CONTINUOUS SHRUB PLANTING**  
NOT TO SCALE

**GENERAL NOTES**

- A/C UNITS, TRANSFORMERS AND OTHER MECHANICAL OR UTILITY EQUIPMENT, NOT SHOWN ON THE PLAN, SHALL BE SCREENED FROM VIEW EITHER BY ADJUSTING PLANTINGS SHOWN IN CLOSE PROXIMITY TO EQUIPMENT OR BY THE ADDITION OF WAX MYRTLES @ 24" HT, 5" OC (SEE GENERAL NOTES FOR EQUIPMENT ACCESSIBILITY AND PLANTING PROXIMITY, ETC.). DUMPSTER IS SCREENED FROM OFF-SITE VIEWS.
- CONTRACTOR SHALL VERIFY LOCATION OF ALL UTILITIES PRIOR TO PLANTING.
- MULCH SHALL BE 3" DEEP SHREDDED HARDWOOD MULCH UNLESS OTHERWISE NOTED.
- VERIFICATION OF TOTAL QUANTITIES AS SHOWN IN THE PLANT LIST AND ON THE PLAN SHALL BE THE RESPONSIBILITY OF THE LANDSCAPE CONTRACTOR. ANY DISCREPANCIES BETWEEN PLANT LIST AND PLANTING PLAN SHALL BE BROUGHT TO THE ATTENTION OF THE LANDSCAPE ARCHITECT FOR CLARIFICATION.
- ALL TREES, SHRUBS, GROUNDCOVER, ETC. SHALL CONFORM TO ACCEPTED STANDARDS ESTABLISHED BY THE AMERICAN ASSOCIATION OF NURSERYMEN.
- ALL ROOTBALLS REMOVED FROM CONTAINERS SHALL BE SCARIFIED PRIOR TO PLANTING.
- B&B AS LISTED UNDER "ROOT" IN THE PLANT LIST INDICATES BALLED & BURLAPPED.
- ALL PLANTS/PLANTINGS SHALL BE MULCHED IMMEDIATELY AFTER PLANTING AND WATERED.
- ALL PLANTS SHALL BEAR THE SAME RELATIONSHIP TO FINISHED GRADE AS THEY BORE TO PREVIOUS EXISTING GRADE (UNLESS OTHERWISE NOTED).
- ALL TREES AND SHRUBS SHALL REQUIRE MULCH RINGS AT THEIR BASE IF LEFT WITHIN LAWN AREAS.
- MULCH EDGES AND PROPOSED PLANTINGS SHALL NOT DISTURB ANY EXISTING GROUPS OF TREES TO REMAIN. EDGES ARE SHOWN FOR APPROXIMATION ONLY, BUT ARE TO INDICATE SMOOTH, CLEAN CURVES.
- CULVERTS, RIP-RAP STRUCTURES, AND OTHER STORMWATER DEVICES SHALL BE SCREENED WITH EVERGREEN SHRUBS. IF STRUCTURES ARE NOT SHOWN ON THE PLAN, INSTALL WAX MYRTLES @ 24" HT. - 5" OC.
- A 2' BUMPER OVERHANG, FROM THE BACK OF CURB, SHALL BE ALLOTTED FOR MATURE SHRUBS.
- TREE PROTECTION FENCING SHALL BE MAINTAINED UNTIL ALL SITE WORK IS COMPLETED. THE FENCING SHALL BE REMOVED PRIOR TO THE FINAL SITE INSPECTION FOR THE CERTIFICATE OF OCCUPANCY (C.O.). THE SITE SHALL BE STABILIZED AND SEEDED PRIOR TO THE ISSUANCE OF A (C.O.).
- UNLESS OTHERWISE NOTED ON THE PLAN, ALL DISTURBED AREAS ARE TO BE SEEDED WITH WARM SEASON GRASS, INCLUDING PARKING LOT PERIMETERS AND PARKING LOT ISLANDS.
- PERIMETER BUFFER AREAS ARE TO BE MULCHED TO A DEPTH OF THREE INCHES.

**LANDSCAPE CALCULATIONS**

PERIMETER BUFFERS (10' TYPICAL):  
 WEST (1) - 352 LF = 4 TREES / 100 LF = 14 TREES REQUIRED/PROVIDED  
 = 40 SHRUBS / 100 LF = 141 SHRUBS REQUIRED/PROVIDED  
 = 352 LF MIN. 6' TALL FENCE REQUIRED

NORTH (2) - 187 LF = 4 TREES / 100 LF = 8 TREES REQUIRED/PROVIDED  
 = 40 SHRUBS / 100 LF = 75 SHRUBS REQUIRED/PROVIDED  
 = 187 LF MIN. 6' TALL FENCE REQUIRED

NORTHEAST (3) - 240 LF = 4 TREES / 100 LF = 10 TREES REQUIRED/PROVIDED  
 = 40 SHRUBS / 100 LF = 96 SHRUBS REQUIRED/PROVIDED  
 = 240 LF MIN. 6' TALL FENCE REQUIRED

EAST (4) - 247 LF = 4 TREES / 100 LF = 10 TREES REQUIRED/PROVIDED  
 = 40 SHRUBS / 100 LF = 100 SHRUBS REQUIRED/PROVIDED  
 = 247 LF MIN. 6' TALL FENCE REQUIRED

STREET YARDS:  
 MAIN ST - 595 LF = 1 TREE / 50 LF = 12 TREES REQUIRED/PROVIDED  
 WEST YOUNG ST - 242 LF = 1 TREE / 50 LF = 5 TREES REQUIRED/PROVIDED

VEHICULAR USE AREA COVERAGE: 1 TREE WITHIN 60' OF EACH PARKING SPACE

**PLANTING NOTES:**

LOCATE PLANTS AND PLANTING BEDS BY USING SCALED DIMENSIONS FROM STREET, PROPERTY LINES, BACK OF CURB, BUILDINGS, WALLS, ETC. ALL PLANTS SHALL MEET OR EXCEED THE MINIMUM STANDARDS SET BY THE U.S.D.A. FOR NURSERY STOCK SPONSORED BY THE AMERICAN ASSOCIATION OF NURSERYMEN, INC., WASHINGTON, D.C. NO SUBSTITUTIONS SHALL BE PERMITTED WITHOUT WRITTEN APPROVAL FROM THE OWNER AND/OR THE LANDSCAPE ARCHITECT. SYMBOLS: B&B = BALLED & BURLAPPED; B.R. = BARE ROOT; CONT. = CONTAINER, O.C. = ON-CENTER

STREET TREE PLANTINGS TO BE COORDINATED IN CONCURRENCE WITH NCDOT STREETSCAPE IMPROVEMENT PROJECT ALONG S. MAIN AND YOUNG STREET(S).

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION


Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer

NO FLOODPLAINS EXIST ON-SITE

NOTE: ALL CONSTRUCTION ACTIVITY MUST BE IN ACCORDANCE WITH THE ACCEPTED POLICIES OF THE TOWN OF ROLESVILLE AND NCDOT

**PLANT SYMBOLS**




**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 881-1122 FAX: (919) 881-6868  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

NO.	DATE	DESCRIPTION	BY
5	02-19-24	PER TOR COMMENTS	GW
4	12-06-23	PER TOR COMMENTS	GW
3	05-16-22	PER TOR COMMENTS	GW
2	04-20-22	PER TOR COMMENTS	GW
1	5-28-21	PER TOR COMMENTS	GW

LANDSCAPE DETAILS  
 CHK BY: GPW  
 SCALE: N.T.S.

**COBBLESTONE VILLAGE**  
**MIXED USE DEVELOPMENT**  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA


SHEET  
**L1.2**



04-19-24

### Outdoor Lighting

#### SHOEBOX LED



**LED**  
(Light-emitting diode) 150220420/330 watts

**Mounting height** 29' - 30'


**Color**  
Black  
Bronze  
Gray (Special conditions)

**Pole**  
Wood  
Style A

IESNA cutoff classification: Full-cutoff  
Color temperature: 3,000K Primary  
4,000K Available

FIXTURE	WATTS	LUMENS	PATTERN	BUG RATING
Shoobox	150	19,017	III	B3-U0-G3
		18,490	IV	B3-U0-G4
		19,380	V	B3-U0-G3
Shoobox	220	29,744	III	B3-U0-G4
		23,061	IV	B3-U0-G4
		24,461	V	B3-U0-G3
Shoobox	420	41,379	IV	B3-U0-G5
		40,868	V	B3-U0-G5
Shoobox	530	51,429	IV	B3-U0-G5
		57,059	V	B3-U0-G5

**LIGHT DISTRIBUTION PATTERNS**



**POLE AVAILABLE**    **MOUNTING HEIGHT**    **FOUNDATION**

Style A	Wood	25', 30', 35'	25', 30', 35'	Direct Bury, Anchor Base	Direct Bury
---------	------	---------------	---------------	--------------------------	-------------

For additional information, contact us at [OOL\\_Care@bnk-engineers.com](mailto:OOL_Care@bnk-engineers.com)

©2023 Bnk Energy Corporation. 23014-1002



**STATISTICS**

AVERAGE	1.8 ft
MAXIMUM	5.6 ft
MINIMUM	0.4 ft
MAXMIN	14.0:1
AVGMIN	4.5:1

**NOTE:**

- BUILDING LIGHTING SHALL BE PROVIDED TO ILLUMINATE ENTRANCES AND EXITS TO MEET IES STANDARDS AS PART OF THE BUILDING ELECTRICAL DESIGN AND IS NOT INCLUDED IN THE SCOPE OF THIS SITE LIGHTING LAYOUT.
- ALL SITE LIGHTING SHALL BE SHIELDED FROM ADJACENT PUBLIC STREETS USING HOUSE SIDE SHIELDS IF GREATER THAN 2.0 FCAT PROPERTY LINE.
- THE INTENT OF THIS DRAWING IS TO SHOW FOOTCANDLE LEVELS BASED ON FIXTURES SHOWN. ACTUAL LEVELS MAY VARY BASED ON ACTUAL FIXTURE INSTALLED.
- THIS DRAWING IS INTENDED FOR PRELIMINARY SITE PLAN APPROVAL OF DESIGNED LIGHTING LEVELS AND IS NOT INTENDED TO BE USED FOR CONSTRUCTION.




**ELECTRICAL CONNECTION NOTE:**

THIS IS A SITE LIGHTING CALCULATION PLAN ONLY AND DOES NOT PROVIDE ELECTRICAL CONNECTIONS FOR FIXTURES SHOWN. SITE DEVELOPERS (OWNERS, BUILDERS AND GENERAL CONTRACTORS) ARE RESPONSIBLE FOR COORDINATING WITH BUILDING ELECTRICAL CONTRACTOR OR POWER COMPANY FOR POWER CONNECTIONS FOR ALL FIXTURES.

**4 FIRST FLOOR SITE LIGHTING**  
SCALE: 1" = 50'-0"

**Lighting Fixture Schedule**


Type Mark	Description	Manufacturer	Model	Voltage	Wattage	Mounting Height
A	NEW LED POLE MOUNTED PARKING LOT LIGHTING	EATON-STREETWORKS	LED 50W SHOEBOX - TYPE IV - 3000K	277 V	59.0 W	25'
B	NEW LED POLE MOUNTED PARKING LOT LIGHTING	EATON-STREETWORKS	LED 150W SHOEBOX - TYPE IV - 4000K	277 V	166.0 W	25'
B1	NEW LED POLE MOUNTED PARKING LOT LIGHTING	EATON-STREETWORKS	LED 150W SHOEBOX - TYPE IV - 4000K	277 V	332.0 W	25'
B2	NEW LED POLE MOUNTED PARKING LOT LIGHTING	EATON-STREETWORKS	LED 150W SHOEBOX - TYPE IV - 4000K	277 V	332.0 W	25'



**2 SITE LIGHTING POLE BASE DETAIL - 5'(6" AFG)**  
SCALE: NONE

**3 FIXTURE "A" & "A2" DETAIL**  
SCALE: NONE






STATE OF NORTH CAROLINA  
 DEPT. OF TRANSPORTATION  
 DIVISION OF HIGHWAYS  
 RALEIGH, N.C.



ROADWAY STANDARD DRAWING FOR  
**CONCRETE CATCH BASIN**  
 12" THRU 54" PIPE

SHEET 1 OF 2  
**840.02**



CITY OF RALEIGH  
 STANDARD DETAIL  
 STANDARD DROP INLET  
**SW-10.03**




CITY OF RALEIGH  
 STANDARD DETAIL  
 STANDARD CLASS "M" MANHOLE  
**SW-10.05**



STATE OF NORTH CAROLINA  
 DEPT. OF TRANSPORTATION  
 DIVISION OF HIGHWAYS  
 RALEIGH, N.C.

ROADWAY STANDARD DRAWING FOR  
**CONCRETE CATCH BASIN**  
 12" THRU 54" PIPE



SHEET 2 OF 2  
**840.02**



STATE OF NORTH CAROLINA  
 DEPT. OF TRANSPORTATION  
 DIVISION OF HIGHWAYS  
 RALEIGH, N.C.

ROADWAY STANDARD DRAWING FOR  
**FRAME, GRATES, AND HOOD**  
 FOR USE ON STANDARD CATCH BASIN

SHEET 1 OF 2  
**840.03**



**BNK**

BASS, NIXON & KENNEDY, INC.  
 CONSULTING ENGINEERS  
 6310 CHAPEL HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919)881-4122 FAX: (919)881-6868  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

PROGRESS	DATE	MRM	BY	DESCRIPTION
3	12-06-23	TOWN OF ROLESVILLE COMMENTS	MRM	
2	10-16-23	T.O.R. COMMENTS	MRM	
1	09-21-23	CHANGES FROM 06-02-22 CDS	MRM	
				NO. DATE

SCALE: N.T.S. CHK BY: MDB

COBBLESTONE VILLAGE MIXED USE DEVELOPMENT  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

SHEET C5.2


CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_  
 Raleigh Water Review Officer




04/19/24




NOTES:  
 1. TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.  
 2. NO ROCKS OR BOULDERS 4" OR LARGER TO BE USED IN INITIAL BACKFILL.  
 3. ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.  
 4. BACKFILL SHALL BE TAMPED IN 6" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.  
 5. ACHIEVE 90% COMPACTION IN NON-TRAFFIC AREAS, AND 95% COMPACTION IN TRAFFIC AREAS.  
 6. IF IN BASEMENT AT TOPSOIL, AND 1" CLEAN GREET FILL MAY BE REQUIRED.  
 7. NO BOULDERS 6" IN DIAMETER OR GREATER ALLOWED IN FINAL BACKFILL.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TRENCH BOTTOM DIMENSIONS & BACKFILLING REQUIREMENTS FOR DUCTILE IRON				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-4	KRT	3-23-00		




NOTES:  
 1. FOR TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.  
 2. NO ROCKS OR BOULDERS 4" OR LARGER TO BE USED IN INITIAL BACKFILL.  
 3. ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.  
 4. BACKFILL SHALL BE TAMPED IN 6" LIFTS IN TRAFFIC AREAS, 12" IN NON-TRAFFIC AREAS.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TRENCH BOTTOM DIMENSIONS AND BACKFILLING REQUIREMENTS FOR PVC GRAVITY SEWER MAIN				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-5	KRT	3-23-00		




NOTES:  
 1. THE TRACER WIRE SHALL BE CONTINUOUS TO THE GREATEST EXTENT POSSIBLE. FOR GRAVITY MAIN AND OR LATERAL INSTALLATIONS LESS THAN 8' FT, THE TRACER WIRE SHALL BE ATTACHED TO THE PIPE TRACER WIRE SHALL BE ADJACENT TO THE PIPE AT 10 FOOT INTERVALS. FOR GRAVITY MAIN AND OR LATERAL INSTALLATION DEEPER THAN 8' FT, THE TRACER WIRE SHALL BE INSTALLED AT A DEPTH OF 7.5 FT. THE WIRE SHALL BE PROTECTED FROM DAMAGE DURING THE COURSE OF THE WORK. NO BREAKS OF CUTS IN THE TRACER WIRE SHALL BE PERMITTED. WHERE LATERAL TAPS ARE MADE BY SERVICE SAIDLES, THE TRACER WIRE SHALL NOT BE ALLOWED TO BE PLACED BETWEEN THE SAIDLE AND MAIN.  
 2. MANHOLE MARKERS SHALL BE PLACED ADJACENT TO MANHOLES AT THE DISCRETION OF OWNER OR OWNER'S REPRESENTATIVE.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
STANDARD PRECAST SANITARY SEWER MANHOLE				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-20	T.G.A.	12-31-02	AKB	2-21-05
	KRT	3-30-00	D.H.L.	6-14-08




NOTES:  
 1. THE TRACER WIRE SHALL BE CONTINUOUS TO THE GREATEST EXTENT POSSIBLE. FOR GRAVITY MAIN AND OR LATERAL INSTALLATIONS LESS THAN 8' FT, THE TRACER WIRE SHALL BE ATTACHED TO THE PIPE TRACER WIRE SHALL BE ADJACENT TO THE PIPE AT 10 FOOT INTERVALS. FOR GRAVITY MAIN AND OR LATERAL INSTALLATION DEEPER THAN 8' FT, THE TRACER WIRE SHALL BE INSTALLED AT A DEPTH OF 7.5 FT. THE WIRE SHALL BE PROTECTED FROM DAMAGE DURING THE COURSE OF THE WORK. NO BREAKS OF CUTS IN THE TRACER WIRE SHALL BE PERMITTED. WHERE LATERAL TAPS ARE MADE BY SERVICE SAIDLES, THE TRACER WIRE SHALL NOT BE ALLOWED TO BE PLACED BETWEEN THE SAIDLE AND MAIN.  
 2. MANHOLE MARKERS SHALL BE PLACED ADJACENT TO MANHOLES AT THE DISCRETION OF OWNER OR OWNER'S REPRESENTATIVE.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
GRAVITY SEWER MAIN TRACER WIRE AND MANHOLE MARKER				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-20A	W.E.	09-11		




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
FLAT TOP MANHOLE COVER				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-25.01	KRT	3-1-07	A.B.B.	2-9-05
	KRT	3-30-00	D.H.L.	6-18-08




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
STANDARD MANHOLE COVER				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-25	KRT	3-1-07	A.B.B.	2-9-05
	KRT	3-30-00	D.H.L.	6-18-08




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
MANHOLE FRAME AND WATERTIGHT COVER				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-26	KRT	3-1-07	AKB	2-23-05
	KRT	3-30-00	D.H.L.	6-18-08




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
STANDARD SLIP RESISTANT MANHOLE STEP DETAIL				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-28	KRT	3-30-00		




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
STANDARD MANHOLE FRAME AND COVER DETAIL WITHIN PAVED SURFACES				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-29	T.G.A.	12-31-02	AKB	3-23-05
	KRT	3-30-00	D.H.L.	11-28-07




NOTES:  
 1. THE TRACER WIRE SHALL BE CONTINUOUS TO THE GREATEST EXTENT POSSIBLE. FOR GRAVITY MAIN AND OR LATERAL INSTALLATIONS LESS THAN 8' FT, THE TRACER WIRE SHALL BE ATTACHED TO THE PIPE TRACER WIRE SHALL BE ADJACENT TO THE PIPE AT 10 FOOT INTERVALS. FOR GRAVITY MAIN AND OR LATERAL INSTALLATION DEEPER THAN 8' FT, THE TRACER WIRE SHALL BE INSTALLED AT A DEPTH OF 7.5 FT. THE WIRE SHALL BE PROTECTED FROM DAMAGE DURING THE COURSE OF THE WORK. NO BREAKS OF CUTS IN THE TRACER WIRE SHALL BE PERMITTED. WHERE LATERAL TAPS ARE MADE BY SERVICE SAIDLES, THE TRACER WIRE SHALL NOT BE ALLOWED TO BE PLACED BETWEEN THE SAIDLE AND MAIN.  
 2. MANHOLE MARKERS SHALL BE PLACED ADJACENT TO MANHOLES AT THE DISCRETION OF OWNER OR OWNER'S REPRESENTATIVE.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TYPICAL SANITARY SEWER LATERAL CONNECTION				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-30	T.G.A.	12-31-02	A.B.B.	4-24-05
	KRT	3-30-00	D.H.L.	11-18-08



NOTES:  
 1. THE TRACER WIRE SHALL BE CONTINUOUS TO THE GREATEST EXTENT POSSIBLE. FOR GRAVITY MAIN AND OR LATERAL INSTALLATIONS LESS THAN 8' FT, THE TRACER WIRE SHALL BE ATTACHED TO THE PIPE TRACER WIRE SHALL BE ADJACENT TO THE PIPE AT 10 FOOT INTERVALS. FOR GRAVITY MAIN AND OR LATERAL INSTALLATION DEEPER THAN 8' FT, THE TRACER WIRE SHALL BE INSTALLED AT A DEPTH OF 7.5 FT. THE WIRE SHALL BE PROTECTED FROM DAMAGE DURING THE COURSE OF THE WORK. NO BREAKS OF CUTS IN THE TRACER WIRE SHALL BE PERMITTED. WHERE LATERAL TAPS ARE MADE BY SERVICE SAIDLES, THE TRACER WIRE SHALL NOT BE ALLOWED TO BE PLACED BETWEEN THE SAIDLE AND MAIN.  
 2. MANHOLE MARKERS SHALL BE PLACED ADJACENT TO MANHOLES AT THE DISCRETION OF OWNER OR OWNER'S REPRESENTATIVE.

CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TYPICAL SANITARY SEWER LATERAL TRACER WIRE				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-30A	W.E.	09-11		




NOTES:  
 1. ALL MANHOLE FRAMES SHALL BE DOMESTICALLY CAST.  
 2. FRAME SHALL BE A MINIMUM WEIGHT OF 120 LBS. WITHIN PUBLIC ROW AND 140 LBS. WITHIN EASEMENTS.  
 3. COVER SHALL WEIGH A MIN. OF 120 LBS.  
 4. ALL MANHOLE FRAMES OUTSIDE OF PAVED SURFACES SHALL BE SET TO THE CORNER SECTION OR RING WITH A MINIMUM OF 4 BOLTS PER FRAME.


CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
4\"/>				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-34	T.G.W.	3-27-05		




CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
CONCRETE CRADLE PROTECTION FOR SEWER LINE CROSSINGS				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-49	PH	2-20-00		




CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
CONCRETE CRADLE PROTECTION FOR SEWER LINE CROSSINGS				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-49	PH	2-20-00		




CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
STANDARD MANHOLE FRAME AND COVER DETAIL WITHIN PAVED SURFACES				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-29	T.G.A.	12-31-02	AKB	3-23-05
	KRT	3-30-00	D.H.L.	11-28-07



CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TYPICAL SANITARY SEWER LATERAL CONNECTION				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-30	T.G.A.	12-31-02	AKB	4-24-05
	KRT	3-30-00	D.H.L.	11-18-08



CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
TYPICAL SANITARY SEWER LATERAL TRACER WIRE				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-30A	W.E.	09-11		



CITY OF RALEIGH DEPARTMENT OF PUBLIC UTILITIES				
4\"/>				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
S-34	T.G.W.	3-27-05		

**BASS, NIXON & KENNEDY, INC.**  
**CONSULTING ENGINEERS**  
 6310 HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 871-7222 FAX: (919) 871-8686  
 CERTIFICATION NUMBERS: NCBELS (C-0119); NCBOLA (C-0267)

PROGRESS	MRM	DATE	DRAWN BY	DATE	COMMENTS	MRM	DATE	DESCRIPTION	BY
3	12-06-23	TOWN OF ROLESVILLE	MM						
2	10-16-23	T.O.R. COMMENTS	MM						
1	09-21-23	CHANGES FROM 06-02-22 CD'S	MM						










**DETAILS**

SCALE: N.T.S.

CHK BY: M.B.

SHEET C5.3

TOWN OF ROLESVILLE PROJECT NO.









**REACTION BEARING AREAS FOR HORIZONTAL WATER PIPE BENDS**  
 BASED ON TEST PRESSURE OF 200 P.S.I.

PIPE AND DEGREE OF BEND	STATIC THRUST IN POUNDS	MIN. AREA (SQ. FT.)	MIN. AREA (SQ. IN.)
6"	11,108	1	1
8"	1,970	1	1
10"	3,822	1	1
12"	4,433	2	3
14"	8,257	2	3
16"	12,252	3	3
18"	15,655	4	5
20"	19,970	5	7
22"	24,206	6	9
24"	27,709	7	11
26"	31,285	8	13
28"	34,851	9	15
30"	38,407	10	17
32"	41,954	11	19
34"	45,492	12	21
36"	49,021	13	23
38"	52,541	14	25
40"	56,052	15	27
42"	59,554	16	29
44"	63,047	17	31
46"	66,532	18	33
48"	70,008	19	35
50"	73,475	20	37
52"	76,933	21	39
54"	80,382	22	41
56"	83,822	23	43
58"	87,253	24	45
60"	90,675	25	47

**REACTION BEARING AREAS FOR HORIZONTAL WATER PIPE BENDS**  
 BASED ON TEST PRESSURE OF 200 P.S.I.

PIPE AND DEGREE OF BEND	STATIC THRUST IN POUNDS	MIN. AREA (SQ. FT.)	MIN. AREA (SQ. IN.)
6"	11,108	1	1
8"	1,970	1	1
10"	3,822	1	1
12"	4,433	2	3
14"	8,257	2	3
16"	12,252	3	3
18"	15,655	4	5
20"	19,970	5	7
22"	24,206	6	9
24"	27,709	7	11
26"	31,285	8	13
28"	34,851	9	15
30"	38,407	10	17
32"	41,954	11	19
34"	45,492	12	21
36"	49,021	13	23
38"	52,541	14	25
40"	56,052	15	27
42"	59,554	16	29
44"	63,047	17	31
46"	66,532	18	33
48"	70,008	19	35
50"	73,475	20	37
52"	76,933	21	39
54"	80,382	22	41
56"	83,822	23	43
58"	87,253	24	45
60"	90,675	25	47



**BASS, NIXON & KENNEDY, INC.**  
 CONSULTING ENGINEERS  
 6310 CHASE HILL ROAD, SUITE 250, RALEIGH, NC 27607  
 TELEPHONE: (919) 881-2222 FAX: (919) 881-6868  
 CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

**COBBLESTONE VILLAGE**  
 MIXED USE DEVELOPMENT  
 TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA

**PROGRESS** MRM DATE DRAWN BY  
 03-18-17 RRH  
**DETAILS** MRM DATE DRAWN BY  
 12-06-23 T.O.R. COMMENTS MRM  
 10-16-23 T.O.R. COMMENTS MRM  
 09-21-23 CHANGES FROM 06-02-22 CD'S MRM  
 NO. DATE DESCRIPTION BY



SCALE: N.T.S. CHK BY: MDB

**SEAL**  
 NORTH CAROLINA  
 PROFESSIONAL ENGINEER  
 MARY D. BIZELLE  
 04/19/24

**SHEET C5.4**







**FLEXIBLE PIPE**

Round Corrugated Steel Pipe 2 1/2 x 1/4 corrugation			
Diameter (Inches)	Minimum cover (Inches)	Maximum Height of Cover (feet)	
12	12	15	24
15	12	18	27
18	12	21	30
21	12	24	33
24	12	27	36
27	12	30	39
30	12	33	42
36	12	39	51
42	12	45	57
48	12	51	63
54	12	57	69
60	12	63	75
66	12	69	81
72	12	75	87
78	12	81	93
84	12	87	99

Round Corrugated Aluminum Pipe 2 1/2 x 1/4 corrugation			
Diameter (Inches)	Minimum cover (Inches)	Maximum Height of Cover (feet)	
12	12	15	24
15	12	18	27
18	12	21	30
21	12	24	33
24	12	27	36
27	12	30	39
30	12	33	42
36	12	39	51
42	12	45	57
48	12	51	63
54	12	57	69
60	12	63	75
66	12	69	81
72	12	75	87
78	12	81	93
84	12	87	99

NOTE: FOR DIFFERENT CORRUGATIONS AND ARCH PIPES REFER TO ROADWAY DESIGN MANUAL OR MANUFACTURER'S SPECIFICATION.

REFER TO THE FOLLOWING FOR PIPE SPECIFICATIONS:  
 CSF - AASHTO M16  
 CSAP - AASHTO M186  
 HOPE - AASHTO M204  
 PVC - ASTM F949 or AASHTO M304







NOTE: FILL HEIGHTS SHOWN WERE CALCULATED USING AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS  
 1" MINIMUM COVER FOR ALL SIDE DRAIN PIPE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS

GENERAL NOTES:  
 1. I.D. = THE MAXIMUM HORIZONTAL INSIDE DIAMETER DIMENSION.  
 O.D. = THE MAXIMUM HORIZONTAL OUTSIDE DIAMETER DIMENSION.  
 H = THE FILL HEIGHT MEASURED VERTICALLY BY ANY METHOD ALONG THE PIPE FROM THE TOP OF THE PIPE TO THE TOP OF THE FOUNDATION AT THAT POINT.  
 \* TAKE CARE TO FULLY COMPACT HATCH ZONE OF PIPE BACKFILL.  
 \*\* LOOSELY PLACED SELECT MATERIAL CLASS III OR CLASS II, TYPE 1 FOR PIPE BEDDING. LINE SECTION SHOULD BE BUILT UP TO PROTECT PIPE FROM WEAR AND SHOULD BE PROTECTED FROM WEAR.

STATE OF NORTH CAROLINA  
DEPT. OF TRANSPORTATION  
DIVISION OF HIGHWAYS  
RALEIGH, N.C.

ROADWAY STANDARD DRAWING FOR  
METHOD OF PIPE INSTALLATION  
RIGID PIPE

SHEET 3 OF 3  
300.01



- NOTES:**
- CONSTRUCT THE RAMP SURFACE TO BE STABLE, FIRM, AND SLIP RESISTANT. CONSTRUCT THE CURB RAMP TYPE AS SHOWN IN THE PAVEMENT MARKING PLANS OR AS DIRECTED BY THE ENGINEER.
  - LOCATE CURB RAMP AND PLACE PEDESTRIAN CROSSWALK MARKINGS AS SHOWN IN THE PAVEMENT MARKING PLANS. WHEN FIELD ADJUSTMENTS REQUIRE MOVING CURB RAMP OR MARKINGS AS SHOWN, CONTACT THE SIGNALING AND DELINEATION UNIT OR LOCATE AS DIRECTED BY THE ENGINEER.
  - COORDINATE THE CURB RAMP AND THE PEDESTRIAN CROSSWALK MARKINGS SO A 4'x4' CLEAR SPACE AT THE BASE OF THE CURB RAMP WILL FALL WITHIN THE PEDESTRIAN CROSSWALK LINES.
  - SET BACK DISTANCE FROM INSIDE CROSSWALK MARKING TO NEAREST EDGE OF TRAVEL LANE IS 4' MINIMUM.
  - REFER TO THE PAVEMENT MARKING PLANS FOR STOP BAR LOCATIONS AT SIGNALIZED INTERSECTIONS. IF A PAVEMENT MARKING PLAN IS NOT PROVIDED, CONTACT THE SIGNAL DESIGN SECTION FOR THE STOP BAR LOCATIONS OR LOCATE AS DIRECTED BY THE ENGINEER.
  - TERMINATE PARKING A MINIMUM OF 20' BACK OF A PEDESTRIAN CROSSWALK.
  - CONSTRUCT CURB RAMP A MINIMUM OF 4' WIDE.
  - CONSTRUCT THE RUNNING SLOPE OF THE RAMP 8.33% MAXIMUM.
  - ALLOWABLE CROSS SLOPE ON SIDEWALKS AND CURB RAMP SURFACES WILL BE 2% MAXIMUM.
  - CONSTRUCT THE SIDE FLARE SLOPE A MAXIMUM OF 10% MEASURED ALONG THE CURB LINE.
  - CONSTRUCT THE COUNTER SLOPE OF THE GUTTER OR STREET AT THE BASE OF THE CURB RAMP A MAXIMUM OF 5% AND MAINTAIN A SMOOTH TRANSITION.
  - CONSTRUCT LANDINGS FOR SIDEWALK A MINIMUM OF 4'x4' WITH A MAXIMUM SLOPE OF 2% IN ANY DIRECTION. CONSTRUCT LANDINGS FOR MEDIAN ISLANDS A MINIMUM OF 5'x5' WITH A MAXIMUM SLOPE OF 2% IN ANY DIRECTION.
  - TO USE A MEDIAN ISLAND AS A PEDESTRIAN REFUGE AREA, MEDIAN ISLANDS WILL BE A MINIMUM OF 6' WIDE. CONSTRUCT MEDIAN ISLANDS TO PROVIDE PASSAGE OVER OR THROUGH THE ISLAND.
  - SMALL CHANNELIZATION ISLANDS THAT CAN NOT PROVIDE A 5'x5' LANDING AT THE TOP OF A RAMP, WILL BE CUT THROUGH LEVEL WITH THE SURFACE STREET.
  - CURB RAMP WITH RETURNED CURBS MAY BE USED ONLY WHERE PEDESTRIANS WOULD NOT NORMALLY WALK ACROSS THE RAMP. THE ADJACENT SURFACE IS PLANTING OR OTHER NON-WALKING SURFACE OR THE SIDE APPROACH IS SUBSTANTIALLY OBSTRUCTED.
  - PLACE ALL PEDESTRIAN PUSH BUTTON ACTUATORS AND CROSSING SIGNALS AS SHOWN IN THE PLANS OR AS SHOWN IN THE MUTCD.
  - CURB RAMP THROUGH MEDIAN ISLANDS, SINGLE RAMP AT DUAL CROSSWALKS OR LIMITED R/W SITUATIONS, WILL BE HANDLED BY SPECIAL DETAILS. CONTACT THE CONTRACT STANDARDS AND DEVELOPMENT UNIT FOR THE DETAILS OR FOR A SPECIAL DESIGN.
- STATE OF NORTH CAROLINA  
DEPT. OF TRANSPORTATION  
DIVISION OF HIGHWAYS  
RALEIGH, N.C.
- ROADWAY STANDARD DRAWING FOR  
CURB RAMP  
NOTES
- SHEET 3 OF 3  
848.05

CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION

Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.

City of Raleigh Development Approval \_\_\_\_\_

Raleigh Water Review Officer \_\_\_\_\_

8/19/24

STATE OF NORTH CAROLINA  
PROFESSIONAL SEAL  
036908  
ENGINEER  
MARTY D. BIZELLE

PROGRESS DATE DRAWN BY MRM  
03-19187 DATE DRAWN BY MRM  
JOB NO. DATE DRAWN BY MRM

3 12-06-23 TOWN OF ROLESVILLE COMMENTS MRM  
2 10-16-23 T.O.R. COMMENTS MRM  
1 09-21-23 CHANGES FROM 06-02-22 CDS MRM

NO. DATE DESCRIPTION REVISIONS  
BY

SCALE: N.T.S. CHK BY: MDB

DETAILED

PROPOSED CURB AND GUTTER

ALLOWABLE LOCATIONS  
DUAL RAMP RADIUS.....ANY

STATE OF NORTH CAROLINA  
DEPT. OF TRANSPORTATION  
DIVISION OF HIGHWAYS  
RALEIGH, N.C.

ROADWAY STANDARD DRAWING FOR  
CURB RAMP  
PROPOSED CURB AND GUTTER

SHEET 3 OF 3  
848.05


**BASS, NIXON & KENNEDY, INC.**  
CONSULTING ENGINEERS  
6310 CHASE HILL ROAD, SUITE 250, RALEIGH, NC 27607  
TELEPHONE: (919) 881-1122 FAX: (919) 881-8686  
CERTIFICATION NUMBERS: NCBELS (C-0110); NCBOLA (C-0267)

**COBBLESTONE VILLAGE MIXED USE DEVELOPMENT**  
TOWN OF ROLESVILLE, WAKE COUNTY, NORTH CAROLINA



**TOWN OF ROLESVILLE PROJECT NO.**

**SHEET C5.6**

NOT RELEASED FOR CONSTRUCTION OR BID SOLICITATION




**MATERIAL SWATCHES - BUILDING 4**  
1" = 1'-0"




**TRANSPARENCY CALCULATIONS**  
 GROUND LEVEL (RETAIL USE): 496 SF  
 TOTAL FACADE AREA (W/H): 496 SF x 0.4 = 198 SF  
 REQD AREA OF TRANSPARENCY: 198 SF 40%  
 AREA OF TRANSPARENCY: 198 SF 40%

Section 7.4 - Town Center Overlay District  
 7.4.18 Windows, doors, display windows and/or arcades shall make up at least 40 percent of the street facade on the first story as measured from two feet above grade to ten feet above grade. Blank walls are not permitted adjacent to streets.



**TRANSPARENCY CALCULATIONS**  
 GROUND LEVEL (RETAIL USE): 1,105 SF  
 TOTAL FACADE AREA (W/H): 1,105 SF x 0.4 = 442 SF  
 REQD AREA OF TRANSPARENCY: 442 SF 40%  
 AREA OF TRANSPARENCY: 442 SF 40%

Section 7.4 - Town Center Overlay District  
 7.4.18 Windows, doors, display windows and/or arcades shall make up at least 40 percent of the street facade on the first story as measured from two feet above grade to ten feet above grade. Blank walls are not permitted adjacent to streets.



**COBBLESTONE VILLAGE**  
ROLESVILLE, NORTH CAROLINA

**EXTERIOR ELEVATIONS - BUILDING 4 A04**  
As indicated | 019032 | 09.01.23



FIBER CEMENT SIDING  
SW7048 - URBANE BRONZE



BRICK VENEER  
TRIANGLE - BESSEMER GREY




3D View BLDG 5 - SE 6




3D View BLDG 5 - NE 5

MAT. SWATCHES - BLDG 5 1  
1" = 1'-0"




BLDG 5 - WEST ELEVATION 4  
1/8" = 1'-0"



BLDG 5 - SOUTH ELEVATION 2  
1/8" = 1'-0"

**TRANSPARENCY CALCULATIONS**  
GROUND LEVEL (RETAIL USE): 824 SF  
TOTAL FACADE AREA (WxH): 824 SF x 0.4 = 330 SF  
REQD AREA OF TRANSPARENCY: 453 SF 55%


Section 7.4 - Town Center Overlay District  
7.4.18 Windows, doors, display windows and/or arcades shall make up at least 40 percent of the street facade on the first story as measured from two feet above grade to ten feet above grade.  
Blank walls are not permitted adjacent to streets.



BLDG 5 - EAST ELEVATION 3  
1/8" = 1'-0"

**TRANSPARENCY CALCULATIONS**  
GROUND LEVEL (RETAIL USE): 412 SF  
TOTAL FACADE AREA (WxH): 412 SF x 0.4 = 165 SF  
REQD AREA OF TRANSPARENCY: 165 SF 40%

Section 7.4 - Town Center Overlay District  
7.4.18 Windows, doors, display windows and/or arcades shall make up at least 40 percent of the street facade on the first story as measured from two feet above grade to ten feet above grade.  
Blank walls are not permitted adjacent to streets.



BLDG 5 - NORTH ELEVATION 1  
1/8" = 1'-0"



**COBBLESTONE VILLAGE**  
ROLESVILLE, NORTH CAROLINA

**EXTERIOR ELEVATIONS - BUILDING 5 A05**  
As indicated | 019032 | 09.01.23



**BLDG 8 - 03 RIGHT SIDE ELEVATION** 4  
1/8" = 1'-0"



**BLDG 8 - 02 REAR ELEVATION** 2  
1/8" = 1'-0"

ROOF BRG. 1 - APTS  
30' - 5 1/4"  
THIRD FLOOR - APTS  
21' - 4"  
SECOND FLOOR - APTS  
10' - 8"  
FIRST FLOOR  
0' - 0"



**BLDG 8 - 04 LEFT SIDE ELEVATION** 3  
1/8" = 1'-0"







**BLDG 8 - 01 FRONT ELEVATION** 1  
1/8" = 1'-0"

ROOF BRG. 1 - APTS  
30' - 5 1/4"  
THIRD FLOOR - APTS  
21' - 4"  
SECOND FLOOR - APTS  
10' - 8"  
FIRST FLOOR  
0' - 0"

ARCHITECTURAL ASPHALT SHINGLES  
FIBER CEMENT BOARD & BATTEN SIDING  
ALUMINUM GUARDRAILS  
MANUFACTURED STONE HEADER  
MANUFACTURED STONE SILL  
MANUFACTURED STONE VENEER

VINYL WINDOWS FIBER CEMENT LAP SIDING FIBER CEMENT LAP SIDING FIBER CEMENT PANEL & TRIM



**COBBLESTONE VILLAGE**  
ROLESVILLE, NORTH CAROLINA

**EXTERIOR ELEVATIONS - BUILDING 8** A08  
1/8" = 1'-0" | 019032 | 09.01.23