## SDP-25-02 – Broadmoor Amenity Center – V2 Submittal review cycle

START DATE: MAY 2025 DUE DATE: \_\_06-09-25\_ TRC/STAFF Comments issued on: \_\_06/06/2025\_

Review Group / Staff	Comments	Cleared Comments
Planning & Zoning – Planning Staff	<ol> <li>Continue to Provide a Written Response to ALL comments / Add revision dates to all submittal materials / Cloud/bubble all changes</li> <li>REPEAT - Address- Add address of amenity center on Cover Sheet and where-ever appropriate.</li> <li>REPEAT - Cover Sheet - Add full and complete legal description entry.</li> </ol>	
Engineering - Jacque Thompson	<ol> <li>See PDF with Mark-ups on Sheet L4.20 only, and these written comments to accompany that:</li> <li>Revise the disturbed area on Note 2 of the Erosion Control Notes to be the acreage of the amenity site only since this project is being done separately, and holding a different permit.</li> <li>Notes 19-21 on the Erosion Control Notes do not seem to apply to the amenity center unless the SCM is needed as an erosion control device. Please clarify and adjust accordingly.</li> <li>The construction entrance on the plan is measuring at 40' but the construction entrance detail shows 50' minimum; please adjust accordingly.</li> <li>The construction entrance detail has overlapping text with what appears to be the vicinity map; please adjust accordingly.</li> </ol>	
Wake County Watershed Mgt – Elizabeth Powell	Broadmoor Amenity Center needs to submit for separate erosion control and stormwater permits with Wake County. We will make comments on those submittals.	TBD
COR Public Utilities - Tim Beasley	<ol> <li>If the stub size is 1", the meter size would also need to be 1". Please verify if this is 1" or ¾". A ¾" tap would use a 5/8" water meter. Please verify and update teh plans accordingly.</li> <li>Please email me for the Raleigh development fees associated with this project. Fees should be paid prior to signatures.</li> </ol>	
Parks & Recreation - Eddie Henderson	There are no comments.	<b>✓</b>
Wake Co Fire / EMS – Stephen Wolf	No fire service issues with current site plan. Once building plans are submitted with a life safety plan, I will be able to determine if the egress plan from the pool deck is code compliant	<b>✓</b>
NCDOT – Jacob Nicholson	No comments were expected/none received.	N/A