



5/21/2025

Developer: ASHTON RALEIGH RESIDENTIAL, LLC.

Contractor: CARDINAL CIVIL CONTRACTING, LLC.

Address: 900 RIDGEFIELD DR., SUITE 335
RALEIGH, NC 27609

Project: HARRIS CREEK SANITARY SEWER REPLACEMENT

Location: Rolesville

Permit #: Sewer: S-5037


Water Main			Gravity Sewer Main			Sewer Force Main		
<u>Diameter</u>	<u>Material</u>	<u>Linear Feet</u>	<u>Diameter</u>	<u>Material</u>	<u>Linear Feet</u>	<u>Diameter</u>	<u>Material</u>	<u>Linear Feet</u>
			24	DIP	391			
			24	PVC	3,054			

Dear Mr./Ms. MARC CHADWICK,

This letter is to advise you that a final inspection has been made on the above referenced project. The inspection is complete and the work is accepted as being in accordance with the construction plans prepared by John R. Harman, P.E. / American Engineering, dated 1/29/2024, and approved on 4/8/2024. As of the completion date of 5/21/2025, the City of Raleigh accepted the infrastructure for continuous maintenance.

This acceptance is subject to a one-year guarantee against failure due to faulty workmanship or materials.

Sincerely,


Janeen Goodwin, PE
Engineering Manager
City of Raleigh
Public Utilities | Raleigh Water