INSPECTION WORKSHEET (997111-2026)
FOR WAKE COUNTY

Case Number:	CBPR-150015-2025	**Case Module:**	Permit
Inspection Date:		**Inspection Status:**	Partial Pass
Inspector:	Matthew McLaughlin - (919) 208-0684	**Inspection Type:**	P&I - Building Final
Job Address:	841 S Main St Rolesville, 27571	**Parcel Number:**	1758454866

Contact Type	Company Name	Name
Applicant	BDG Architects	BDG Architects
Electrical Contractor	P3 Electric	Vicki Brown
General Contractor	Potter Construction Services	Sheree Logan
Mechanical Contractor	Empower Service Solutions LLC	Jerry Canipe
Plumbing Contractor	Capitol Plumbing, LLC	David Lombardo

Checklist Item	Results	Comments
General Comments - Checklist item used to track general comments, not specific to any other checklist item	Fail	10/27/26 - VWW - Building Final 1. Provie sealed soils evaluation letter from footing inspection 2. Building numbers on street facing side of building 3. Address Fire Services Inspection Items 4. Add cap at clean out access at rear of building on exterior 5. Trade inspections to be passed
General Comments - Checklist item used to track general comments, not specific to any other checklist item	Fail	10/28/26 Building Final MFM Provie sealed soils evaluation letter from footing 1. Seal opening at 4” pipe in drive through 2. ADA signage. I've spoken with the fire marshal, and we agree that stocking permit can be issued. The building is safe.