



4/2/2026

Developer: HOPPER COMMUNITIES, INC.
 Contractor: MARKS CLEARING AND GRADING
 Address: 1616 CLEVELAND AVE.
 CHARLOTTE, NC 28203
 Project: ROLESVILLE CROSSING PHASE 2
 Location: Rolesville
 Permit #: Water: W-4081 Sewer: S-5396

Water Main			Gravity Sewer Main			Sewer Force Main		
Diameter	Material	Linear Feet	Diameter	Material	Linear Feet	Diameter	Material	Linear Feet
8	DIP	5,400	8	PVC	3,354			
			8	DIP	1,117			
			12	PVC	215			
			12	DIP	173			

Dear Mr./Ms. HOPPER COMMUNITIES, INC.,

This letter is to advise you that a final inspection has been made on the above referenced project. The inspection is complete and the work is accepted as being in accordance with the construction plans prepared by PATRICK J. BARBEAU, P.E. / TIMMONS GROUP, dated 1/2/2024, and approved on 2/26/2024. As of the completion date of 4/2/2026, the City of Raleigh accepted the infrastructure for continuous maintenance.

This acceptance is subject to a one-year guarantee against failure due to faulty workmanship or materials.

Sincerely,
 Signed by:

Aaron Bennett
 Aaron S. Bennett, P.E.
 Engineering Manager
 City of Raleigh
 Public Utilities | Raleigh Water