



HIGHFILL

Highfill Infrastructure Engineering, P.C.
2703 Jones Franklin Road, Suite 201
Cary, North Carolina 27518
Tel 919-481-4342 | NC Firm License No. C-2586

February 28, 2023

Mr. Mike Elabarger
Senior Planner
Town of Rolesville
P.O. Box 250
502 Southtown Circle
Rolesville, NC 27571

RE: CD 22-06 – Wallbrook Off-Site Sewer
3rd Submittal Review with 2nd Review Cycle Comments Addressed
HIGHFILL Project No.: CSE2201

Dear Mr. Elabarger:

We are in receipt of the 2nd Submittal Review Cycle comments dated 2/1/2023. The following are the comment responses:

Town of Rolesville Planning Department – Mike Elabarger:

- Revision date is included on the revision block. This comment response letter is provided.

Wake County Watershed Management – Janet Boyer:

- Comments received from Janet Boyer on 2/7/2023. Comments are being responded to separately of this review cycle.

City of Raleigh Public Utilities – Tim Beasley:

- City of Raleigh Public Sewer Permit Application was sent to Tim Beasley. A Permit Number has been added to the construction drawings.
- We will submit for signatures when the Wake County Erosion Control Permit is approved.
- On Sheet C-1.0, at ~STA 17+05, we added a 10 LF steel encasement pipe over the concrete cradle for protection of the sewer line.

Engineering (B&M) – Brian Laux/Jacque Thompson:

- No comments received.

Wake County Fire / EMS – Brittany Hocutt:

- No comments received.

Mr. Elabarger
February 28, 2023

Parks & Recreation – JG Ferguson and Eddie Henderson:

- Carlton Pointe HOA has been informed of the project.

Sincerely,

HIGHFILL INFRASTRUCTURE ENGINEERING, P.C.

A handwritten signature in blue ink that reads "Brian J.P. Oswald". The signature is written in a cursive style with a large initial "B" and "O".

Brian J.P. Oswald, PE
Senior Project Manager